



Ref. Certif. No.

FR_718643

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker for overcurrent protection for household and similar installations

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendes France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendes France, Eybens
38050 GRENOBLE Cedex 9
FRANCE

Name and address of the factory

See annex

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Resi9 Biconnect 10000 Series, 10R9Bxxx

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_702466 dated 06/03/2018 . Update further to the evolution of the standard(s)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 +A1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

17522071_785339 Version 01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature:  Didier Bourges
Manager of Certification Operations



ANNEX

Name and address of the factories:**Schneider Electric India Pvt. Ltd.**

Plot No - 172, Poonamallee Bye Pass Road, Poonamallee, Tamil Nadu
600056 CHENNAI
INDIA

SCHNEIDER ELECTRIC BULGARIA EOOD

Plovdiv plant
4202 RADINOVO PLOVDIV
BULGARIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGES
Manager of Certification Operations



Product Name	Rated Short-circuit capacity Icn	Voltage in V	Poles	Rating	Curve	Generic reference
Resi9 biconnect 10000	10000	230 or 240	1P	1	B	10R9B1B1
Resi9 biconnect 10000	10000	230 or 240	1P	2	B	10R9B1B2
Resi9 biconnect 10000	10000	230 or 240	1P	3	B	10R9B1B3
Resi9 biconnect 10000	10000	230 or 240	1P	4	B	10R9B1B4
Resi9 biconnect 10000	10000	230 or 240	1P	6	B	10R9B1B6
Resi9 biconnect 10000	10000	230 or 240	1P	8	B	10R9B1B8
Resi9 biconnect 10000	10000	230 or 240	1P	10	B	10R9B1B10
Resi9 biconnect 10000	10000	230 or 240	1P	13	B	10R9B1B13
Resi9 biconnect 10000	10000	230 or 240	1P	16	B	10R9B1B16
Resi9 biconnect 10000	10000	230 or 240	1P	20	B	10R9B1B20
Resi9 biconnect 10000	10000	230 or 240	1P	25	B	10R9B1B25
Resi9 biconnect 10000	10000	230 or 240	1P	32	B	10R9B1B32
Resi9 biconnect 10000	10000	230 or 240	1P	40	B	10R9B1B40
Resi9 biconnect 10000	10000	230 or 240	1P	50	B	10R9B1B50
Resi9 biconnect 10000	10000	230 or 240	1P	63	B	10R9B1B63
Resi9 biconnect 10000	10000	230 or 240	1P+N	1	B	10R9BPhNB1
Resi9 biconnect 10000	10000	230 or 240	1P+N	2	B	10R9BPhNB2
Resi9 biconnect 10000	10000	230 or 240	1P+N	3	B	10R9BPhNB3
Resi9 biconnect 10000	10000	230 or 240	1P+N	4	B	10R9BPhNB4
Resi9 biconnect 10000	10000	230 or 240	1P+N	6	B	10R9BPhNB6
Resi9 biconnect 10000	10000	230 or 240	1P+N	8	B	10R9BPhNB8
Resi9 biconnect 10000	10000	230 or 240	1P+N	10	B	10R9BPhNB10
Resi9 biconnect 10000	10000	230 or 240	1P+N	13	B	10R9BPhNB13
Resi9 biconnect 10000	10000	230 or 240	1P+N	16	B	10R9BPhNB16
Resi9 biconnect 10000	10000	230 or 240	1P+N	20	B	10R9BPhNB20
Resi9 biconnect 10000	10000	230 or 240	1P+N	25	B	10R9BPhNB25
Resi9 biconnect 10000	10000	230 or 240	1P+N	32	B	10R9BPhNB32
Resi9 biconnect 10000	10000	230 or 240	1P+N	40	B	10R9BPhNB40
Resi9 biconnect 10000	10000	230 or 240	1P+N	50	B	10R9BPhNB50
Resi9 biconnect 10000	10000	230 or 240	1P+N	63	B	10R9BPhNB63
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	1	B	10R9BPhNRB1
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	2	B	10R9BPhNRB2
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	3	B	10R9BPhNRB3



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGIES
 Manager of Certification Operations




Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	4	B	10R9BPhNRB4
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	6	B	10R9BPhNRB6
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	8	B	10R9BPhNRB8
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	10	B	10R9BPhNRB10
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	13	B	10R9BPhNRB13
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	16	B	10R9BPhNRB16
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	20	B	10R9BPhNRB20
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	25	B	10R9BPhNRB25
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	32	B	10R9BPhNRB32
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	40	B	10R9BPhNRB40
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	50	B	10R9BPhNRB50
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	63	B	10R9BPhNRB63
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	1	B	10R9B2B1
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	2	B	10R9B2B2
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	3	B	10R9B2B3
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	4	B	10R9B2B4
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	6	B	10R9B2B6
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	8	B	10R9B2B8
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	10	B	10R9B2B10
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	13	B	10R9B2B13
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	16	B	10R9B2B16
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	20	B	10R9B2B20
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	25	B	10R9B2B25
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	32	B	10R9B2B32
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	40	B	10R9B2B40
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	50	B	10R9B2B50
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	63	B	10R9B2B63
Resi9 biconnect 10000	10000	400 or 415	3P	1	B	10R9B3B1
Resi9 biconnect 10000	10000	400 or 415	3P	2	B	10R9B3B2
Resi9 biconnect 10000	10000	400 or 415	3P	3	B	10R9B3B3
Resi9 biconnect 10000	10000	400 or 415	3P	4	B	10R9B3B4
Resi9 biconnect 10000	10000	400 or 415	3P	6	B	10R9B3B6
Resi9 biconnect 10000	10000	400 or 415	3P	8	B	10R9B3B8
Resi9 biconnect 10000	10000	400 or 415	3P	10	B	10R9B3B10



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier ROYER
 Manager of Certification Operations




Resi9 biconnect 10000	10000	400 or415	3P	13	B	10R9B3B13
Resi9 biconnect 10000	10000	400 or415	3P	16	B	10R9B3B16
Resi9 biconnect 10000	10000	400 or415	3P	20	B	10R9B3B20
Resi9 biconnect 10000	10000	400 or415	3P	25	B	10R9B3B25
Resi9 biconnect 10000	10000	400 or415	3P	32	B	10R9B3B32
Resi9 biconnect 10000	10000	400 or415	3P	40	B	10R9B3B40
Resi9 biconnect 10000	10000	400 or415	3P	50	B	10R9B3B50
Resi9 biconnect 10000	10000	400 or415	3P	63	B	10R9B3B63
Resi9 biconnect 10000	10000	400 or 415	3P+N	1	B	10R9B3phNB1
Resi9 biconnect 10000	10000	400 or415	3P+N	2	B	10R9B3phNB2
Resi9 biconnect 10000	10000	400 or415	3P+N	3	B	10R9B3phNB3
Resi9 biconnect 10000	10000	400 or415	3P+N	4	B	10R9B3phNB4
Resi9 biconnect 10000	10000	400 or415	3P+N	6	B	10R9B3phNB6
Resi9 biconnect 10000	10000	400 or415	3P+N	8	B	10R9B3phNB8
Resi9 biconnect 10000	10000	400 or415	3P+N	10	B	10R9B3phNB10
Resi9 biconnect 10000	10000	400 or415	3P+N	13	B	10R9B3phNB13
Resi9 biconnect 10000	10000	400 or415	3P+N	16	B	10R9B3phNB16
Resi9 biconnect 10000	10000	400 or415	3P+N	20	B	10R9B3phNB20
Resi9 biconnect 10000	10000	400 or415	3P+N	25	B	10R9B3phNB25
Resi9 biconnect 10000	10000	400 or415	3P+N	32	B	10R9B3phNB32
Resi9 biconnect 10000	10000	400 or415	3P+N	40	B	10R9B3phNB40
Resi9 biconnect 10000	10000	400 or415	3P+N	50	B	10R9B3phNB50
Resi9 biconnect 10000	10000	400 or415	3P+N	63	B	10R9B3phNB63
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	1	B	10R9B3phNRB1
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	2	B	10R9B3phNRB2
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	3	B	10R9B3phNRB3
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	4	B	10R9B3phNRB4
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	6	B	10R9B3phNRB6
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	8	B	10R9B3phNRB8
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	10	B	10R9B3phNRB10
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	13	B	10R9B3phNRB13
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	16	B	10R9B3phNRB16
Resi9 biconnect 10000	10000	400 or415	3P+N(*)	20	B	10R9B3phNRB20
Resi9 biconnect 10000	10000	400 or415	3P+N(*)	25	B	10R9B3phNRB25



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGOIN
 Manager of Certification Operations



Resi9 biconnect 10000	10000	400 or415	3P+N(*)	32	B	10R9B3phNRB32
Resi9 biconnect 10000	10000	400 or415	3P+N(*)	40	B	10R9B3phNRB40
Resi9 biconnect 10000	10000	400 or415	3P+N(*)	50	B	10R9B3phNRB50
Resi9 biconnect 10000	10000	400 or415	3P+N(*)	63	B	10R9B3phNRB63
Resi9 biconnect 10000	10000	400 or 415	4P	1	B	10R9B4B1
Resi9 biconnect 10000	10000	400 or415	4P	2	B	10R9B4B2
Resi9 biconnect 10000	10000	400 or415	4P	3	B	10R9B4B3
Resi9 biconnect 10000	10000	400 or415	4P	4	B	10R9B4B4
Resi9 biconnect 10000	10000	400 or415	4P	6	B	10R9B4B6
Resi9 biconnect 10000	10000	400 or415	4P	8	B	10R9B4B8
Resi9 biconnect 10000	10000	400 or415	4P	10	B	10R9B4B10
Resi9 biconnect 10000	10000	400 or415	4P	13	B	10R9B4B13
Resi9 biconnect 10000	10000	400 or415	4P	16	B	10R9B4B16
Resi9 biconnect 10000	10000	400 or415	4P	20	B	10R9B4B20
Resi9 biconnect 10000	10000	400 or415	4P	25	B	10R9B4B25
Resi9 biconnect 10000	10000	400 or415	4P	32	B	10R9B4B32
Resi9 biconnect 10000	10000	400 or415	4P	40	B	10R9B4B40
Resi9 biconnect 10000	10000	400 or415	4P	50	B	10R9B4B50
Resi9 biconnect 10000	10000	400 or415	4P	63	B	10R9B4B63
Resi9 biconnect 10000	10000	230 or 240	1P	0.5	C	10R9B1C0.5
Resi9 biconnect 10000	10000	230 or 240	1P	0.75	C	10R9B1C0.75
Resi9 biconnect 10000	10000	230 or 240	1P	1	C	10R9B1C1
Resi9 biconnect 10000	10000	230 or 240	1P	2	C	10R9B1C2
Resi9 biconnect 10000	10000	230 or 240	1P	3	C	10R9B1C3
Resi9 biconnect 10000	10000	230 or 240	1P	4	C	10R9B1C4
Resi9 biconnect 10000	10000	230 or 240	1P	6	C	10R9B1C6
Resi9 biconnect 10000	10000	230 or 240	1P	8	C	10R9B1C8
Resi9 biconnect 10000	10000	230 or 240	1P	10	C	10R9B1C10
Resi9 biconnect 10000	10000	230 or 240	1P	13	C	10R9B1C13
Resi9 biconnect 10000	10000	230 or 240	1P	16	C	10R9B1C16
Resi9 biconnect 10000	10000	230 or 240	1P	20	C	10R9B1C20
Resi9 biconnect 10000	10000	230 or 240	1P	25	C	10R9B1C25
Resi9 biconnect 10000	10000	230 or 240	1P	32	C	10R9B1C32



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGE
 Manager of Certification Operations



Resi9 biconnect 10000	10000	230 or 240	1P	40	C	10R9B1C40
Resi9 biconnect 10000	10000	230 or 240	1P	50	C	10R9B1C50
Resi9 biconnect 10000	10000	230 or 240	1P	63	C	10R9B1C63
Resi9 biconnect 10000	10000	230 or 240	1P+N	0.5	C	10R9BPhNC0.5
Resi9 biconnect 10000	10000	230 or 240	1P+N	0.75	C	10R9BPhNC0.75
Resi9 biconnect 10000	10000	230 or 240	1P+N	1	C	10R9BPhNC1
Resi9 biconnect 10000	10000	230 or 240	1P+N	2	C	10R9BPhNC2
Resi9 biconnect 10000	10000	230 or 240	1P+N	3	C	10R9BPhNC3
Resi9 biconnect 10000	10000	230 or 240	1P+N	4	C	10R9BPhNC4
Resi9 biconnect 10000	10000	230 or 240	1P+N	6	C	10R9BPhNC6
Resi9 biconnect 10000	10000	230 or 240	1P+N	8	C	10R9BPhNC8
Resi9 biconnect 10000	10000	230 or 240	1P+N	10	C	10R9BPhNC10
Resi9 biconnect 10000	10000	230 or 240	1P+N	13	C	10R9BPhNC13
Resi9 biconnect 10000	10000	230 or 240	1P+N	16	C	10R9BPhNC16
Resi9 biconnect 10000	10000	230 or 240	1P+N	20	C	10R9BPhNC20
Resi9 biconnect 10000	10000	230 or 240	1P+N	25	C	10R9BPhNC25
Resi9 biconnect 10000	10000	230 or 240	1P+N	32	C	10R9BPhNC32
Resi9 biconnect 10000	10000	230 or 240	1P+N	40	C	10R9BPhNC40
Resi9 biconnect 10000	10000	230 or 240	1P+N	50	C	10R9BPhNC50
Resi9 biconnect 10000	10000	230 or 240	1P+N	63	C	10R9BPhNC63
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	0.5	C	10R9BPhNRC0.5
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	0.75	C	10R9BPhNRC0.75
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	1	C	10R9BPhNRC1
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	2	C	10R9BPhNRC2
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	3	C	10R9BPhNRC3
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	4	C	10R9BPhNRC4
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	6	C	10R9BPhNRC6
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	8	C	10R9BPhNRC8
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	10	C	10R9BPhNRC10
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	13	C	10R9BPhNRC13
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	16	C	10R9BPhNRC16
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	20	C	10R9BPhNRC20
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	25	C	10R9BPhNRC25
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	32	C	10R9BPhNRC32



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGES
 Manager of LCIE Field Operations




Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	40	C	10R9BPhNRC40
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	50	C	10R9BPhNRC50
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	63	C	10R9BPhNRC63
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	0.5	C	10R9B2C0.5
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	0.75	C	10R9B2C0.75
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	1	C	10R9B2C1
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	2	C	10R9B2C2
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	3	C	10R9B2C3
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	4	C	10R9B2C4
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	6	C	10R9B2C6
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	8	C	10R9B2C8
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	10	C	10R9B2C10
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	13	C	10R9B2C13
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	16	C	10R9B2C16
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	20	C	10R9B2C20
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	25	C	10R9B2C25
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	32	C	10R9B2C32
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	40	C	10R9B2C40
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	50	C	10R9B2C50
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	63	C	10R9B2C63
Resi9 biconnect 10000	10000	400 or 415	3P	0.5	C	10R9B3C0.5
Resi9 biconnect 10000	10000	400 or 415	3P	0.75	C	10R9B3C0.75
Resi9 biconnect 10000	10000	400 or 415	3P	1	C	10R9B3C1
Resi9 biconnect 10000	10000	400 or 415	3P	2	C	10R9B3C2
Resi9 biconnect 10000	10000	400 or 415	3P	3	C	10R9B3C3
Resi9 biconnect 10000	10000	400 or 415	3P	4	C	10R9B3C4
Resi9 biconnect 10000	10000	400 or 415	3P	6	C	10R9B3C6
Resi9 biconnect 10000	10000	400 or 415	3P	8	C	10R9B3C8
Resi9 biconnect 10000	10000	400 or 415	3P	10	C	10R9B3C10
Resi9 biconnect 10000	10000	400 or 415	3P	13	C	10R9B3C13
Resi9 biconnect 10000	10000	400 or 415	3P	16	C	10R9B3C16
Resi9 biconnect 10000	10000	400 or 415	3P	20	C	10R9B3C20
Resi9 biconnect 10000	10000	400 or 415	3P	25	C	10R9B3C25
Resi9 biconnect 10000	10000	400 or 415	3P	32	C	10R9B3C32



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGES
 Manager of Certification Operations



Resi9 biconnect 10000	10000	400 or 415	3P	40	C	10R9B3C40
Resi9 biconnect 10000	10000	400 or 415	3P	50	C	10R9B3C50
Resi9 biconnect 10000	10000	400 or 415	3P	63	C	10R9B3C63
Resi9 biconnect 10000	10000	400 or 415	3P+N	0.5	C	10R9B3phNC0.5
Resi9 biconnect 10000	10000	400 or 415	3P+N	0.75	C	10R9B3phNC0.75
Resi9 biconnect 10000	10000	400 or 415	3P+N	1	C	10R9B3phNC1
Resi9 biconnect 10000	10000	400 or 415	3P+N	2	C	10R9B3phNC2
Resi9 biconnect 10000	10000	400 or 415	3P+N	3	C	10R9B3phNC3
Resi9 biconnect 10000	10000	400 or 415	3P+N	4	C	10R9B3phNC4
Resi9 biconnect 10000	10000	400 or 415	3P+N	6	C	10R9B3phNC6
Resi9 biconnect 10000	10000	400 or 415	3P+N	8	C	10R9B3phNC8
Resi9 biconnect 10000	10000	400 or 415	3P+N	10	C	10R9B3phNC10
Resi9 biconnect 10000	10000	400 or 415	3P+N	13	C	10R9B3phNC13
Resi9 biconnect 10000	10000	400 or 415	3P+N	16	C	10R9B3phNC16
Resi9 biconnect 10000	10000	400 or 415	3P+N	20	C	10R9B3phNC20
Resi9 biconnect 10000	10000	400 or 415	3P+N	25	C	10R9B3phNC25
Resi9 biconnect 10000	10000	400 or 415	3P+N	32	C	10R9B3phNC32
Resi9 biconnect 10000	10000	400 or 415	3P+N	40	C	10R9B3phNC40
Resi9 biconnect 10000	10000	400 or 415	3P+N	50	C	10R9B3phNC50
Resi9 biconnect 10000	10000	400 or 415	3P+N	63	C	10R9B3phNC63
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	0.5	C	10R9B3phNRC0.5
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	0.75	C	10R9B3phNRC0.75
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	1	C	10R9B3phNRC1
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	2	C	10R9B3phNRC2
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	3	C	10R9B3phNRC3
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	4	C	10R9B3phNRC4
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	6	C	10R9B3phNRC6
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	8	C	10R9B3phNRC8
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	10	C	10R9B3phNRC10
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	13	C	10R9B3phNRC13
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	16	C	10R9B3phNRC16
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	20	C	10R9B3phNRC20
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	25	C	10R9B3phNRC25
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	32	C	10R9B3phNRC32



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOUGES
 Manager of Certification Operations



Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	40	C	10R9B3phNRC40
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	50	C	10R9B3phNRC50
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	63	C	10R9B3phNRC63
Resi9 biconnect 10000	10000	400 or 415	4P	0.5	C	10R9B4C0.5
Resi9 biconnect 10000	10000	400 or 415	4P	0.75	C	10R9B4C0.75
Resi9 biconnect 10000	10000	400 or 415	4P	1	C	10R9B4C1
Resi9 biconnect 10000	10000	400 or 415	4P	2	C	10R9B4C2
Resi9 biconnect 10000	10000	400 or 415	4P	3	C	10R9B4C3
Resi9 biconnect 10000	10000	400 or 415	4P	4	C	10R9B4C4
Resi9 biconnect 10000	10000	400 or 415	4P	6	C	10R9B4C6
Resi9 biconnect 10000	10000	400 or 415	4P	8	C	10R9B4C8
Resi9 biconnect 10000	10000	400 or 415	4P	10	C	10R9B4C10
Resi9 biconnect 10000	10000	400 or 415	4P	13	C	10R9B4C13
Resi9 biconnect 10000	10000	400 or 415	4P	16	C	10R9B4C16
Resi9 biconnect 10000	10000	400 or 415	4P	20	C	10R9B4C20
Resi9 biconnect 10000	10000	400 or 415	4P	25	C	10R9B4C25
Resi9 biconnect 10000	10000	400 or 415	4P	32	C	10R9B4C32
Resi9 biconnect 10000	10000	400 or 415	4P	40	C	10R9B4C40
Resi9 biconnect 10000	10000	400 or 415	4P	50	C	10R9B4C50
Resi9 biconnect 10000	10000	400 or 415	4P	63	C	10R9B4C63
Resi9 biconnect 10000	10000	230 or 240	1P	0.5	D	10R9B1D0.5
Resi9 biconnect 10000	10000	230 or 240	1P	0.75	D	10R9B1D0.75
Resi9 biconnect 10000	10000	230 or 240	1P	1	D	10R9B1D1
Resi9 biconnect 10000	10000	230 or 240	1P	2	D	10R9B1D2
Resi9 biconnect 10000	10000	230 or 240	1P	3	D	10R9B1D3
Resi9 biconnect 10000	10000	230 or 240	1P	4	D	10R9B1D4
Resi9 biconnect 10000	10000	230 or 240	1P	6	D	10R9B1D6
Resi9 biconnect 10000	10000	230 or 240	1P	8	D	10R9B1D8
Resi9 biconnect 10000	10000	230 or 240	1P	10	D	10R9B1D10
Resi9 biconnect 10000	10000	230 or 240	1P	13	D	10R9B1D13
Resi9 biconnect 10000	10000	230 or 240	1P	16	D	10R9B1D16
Resi9 biconnect 10000	10000	230 or 240	1P	20	D	10R9B1D20
Resi9 biconnect 10000	10000	230 or 240	1P	25	D	10R9B1D25
Resi9 biconnect 10000	10000	230 or 240	1P	32	D	10R9B1D32



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGES
 Manager of Certification Operations



Resi9 biconnect 10000	10000	230 or 240	1P	40	D	10R9B1D40
Resi9 biconnect 10000	6000	230 or 240	1P	50	D	10R9B1D50
Resi9 biconnect 10000	6000	230 or 240	1P	63	D	10R9B1D63
Resi9 biconnect 10000	10000	230 or 240	1P+N	0.5	D	10R9BPhND0.5
Resi9 biconnect 10000	10000	230 or 240	1P+N	0.75	D	10R9BPhND0.75
Resi9 biconnect 10000	10000	230 or 240	1P+N	1	D	10R9BPhND1
Resi9 biconnect 10000	10000	230 or 240	1P+N	2	D	10R9BPhND2
Resi9 biconnect 10000	10000	230 or 240	1P+N	3	D	10R9BPhND3
Resi9 biconnect 10000	10000	230 or 240	1P+N	4	D	10R9BPhND4
Resi9 biconnect 10000	10000	230 or 240	1P+N	6	D	10R9BPhND6
Resi9 biconnect 10000	10000	230 or 240	1P+N	8	D	10R9BPhND8
Resi9 biconnect 10000	10000	230 or 240	1P+N	10	D	10R9BPhND10
Resi9 biconnect 10000	10000	230 or 240	1P+N	13	D	10R9BPhND13
Resi9 biconnect 10000	10000	230 or 240	1P+N	16	D	10R9BPhND16
Resi9 biconnect 10000	10000	230 or 240	1P+N	20	D	10R9BPhND20
Resi9 biconnect 10000	10000	230 or 240	1P+N	25	D	10R9BPhND25
Resi9 biconnect 10000	10000	230 or 240	1P+N	32	D	10R9BPhND32
Resi9 biconnect 10000	10000	230 or 240	1P+N	40	D	10R9BPhND40
Resi9 biconnect 10000	6000	230 or 240	1P+N	50	D	10R9BPhND50
Resi9 biconnect 10000	6000	230 or 240	1P+N	63	D	10R9BPhND63
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	0.5	D	10R9BPhNRD0.5
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	0.75	D	10R9BPhNRD0.75
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	1	D	10R9BPhNRD1
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	2	D	10R9BPhNRD2
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	3	D	10R9BPhNRD3
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	4	D	10R9BPhNRD4
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	6	D	10R9BPhNRD6
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	8	D	10R9BPhNRD8
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	10	D	10R9BPhNRD10
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	13	D	10R9BPhNRD13
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	16	D	10R9BPhNRD16
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	20	D	10R9BPhNRD20
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	25	D	10R9BPhNRD25
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	32	D	10R9BPhNRD32
Resi9 biconnect 10000	10000	230 or 240	1P+N(*)	40	D	10R9BPhNRD40



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURGES
 Manager of Certification Operations



Resi9 biconnect 10000	6000	230 or 240	1P+N(*)	50	D	10R9BPhNRD50
Resi9 biconnect 10000	6000	230 or 240	1P+N(*)	63	D	10R9BPhNRD63
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	0.5	D	10R9B2D0.5
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	0.75	D	10R9B2D0.75
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	1	D	10R9B2D1
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	2	D	10R9B2D2
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	3	D	10R9B2D3
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	4	D	10R9B2D4
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	6	D	10R9B2D6
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	8	D	10R9B2D8
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	10	D	10R9B2D10
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	13	D	10R9B2D13
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	16	D	10R9B2D16
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	20	D	10R9B2D20
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	25	D	10R9B2D25
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	32	D	10R9B2D32
Resi9 biconnect 10000	10000	230,240,400 or 415	2P	40	D	10R9B2D40
Resi9 biconnect 10000	6000	230,240,400 or 415	2P	50	D	10R9B2D50
Resi9 biconnect 10000	6000	230,240,400 or 415	2P	63	D	10R9B2D63
Resi9 biconnect 10000	10000	400 or 415	3P	0.5	D	10R9B3D0.5
Resi9 biconnect 10000	10000	400 or 415	3P	0.75	D	10R9B3D0.75
Resi9 biconnect 10000	10000	400 or 415	3P	1	D	10R9B3D1
Resi9 biconnect 10000	10000	400 or 415	3P	2	D	10R9B3D2
Resi9 biconnect 10000	10000	400 or 415	3P	3	D	10R9B3D3
Resi9 biconnect 10000	10000	400 or 415	3P	4	D	10R9B3D4
Resi9 biconnect 10000	10000	400 or 415	3P	6	D	10R9B3D6
Resi9 biconnect 10000	10000	400 or 415	3P	8	D	10R9B3D8
Resi9 biconnect 10000	10000	400 or 415	3P	10	D	10R9B3D10
Resi9 biconnect 10000	10000	400 or 415	3P	13	D	10R9B3D13
Resi9 biconnect 10000	10000	400 or 415	3P	16	D	10R9B3D16
Resi9 biconnect 10000	10000	400 or 415	3P	20	D	10R9B3D20
Resi9 biconnect 10000	10000	400 or 415	3P	25	D	10R9B3D25
Resi9 biconnect 10000	10000	400 or 415	3P	32	D	10R9B3D32
Resi9 biconnect 10000	10000	400 or 415	3P	40	D	10R9B3D40
Resi9 biconnect 10000	6000	400 or 415	3P	50	D	10R9B3D50



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

 Signature: Didier BOURGES
 Manager of Certification Operations


Resi9 biconnect 10000	6000	400 or 415	3P	63	D	10R9B3D63
Resi9 biconnect 10000	10000	400 or 415	3P+N	0.5	D	10R9B3phND0.5
Resi9 biconnect 10000	10000	400 or 415	3P+N	0.75	D	10R9B3phND0.75
Resi9 biconnect 10000	10000	400 or 415	3P+N	1	D	10R9B3phND1
Resi9 biconnect 10000	10000	400 or 415	3P+N	2	D	10R9B3phND2
Resi9 biconnect 10000	10000	400 or 415	3P+N	3	D	10R9B3phND3
Resi9 biconnect 10000	10000	400 or 415	3P+N	4	D	10R9B3phND4
Resi9 biconnect 10000	10000	400 or 415	3P+N	6	D	10R9B3phND6
Resi9 biconnect 10000	10000	400 or 415	3P+N	8	D	10R9B3phND8
Resi9 biconnect 10000	10000	400 or 415	3P+N	10	D	10R9B3phND10
Resi9 biconnect 10000	10000	400 or 415	3P+N	13	D	10R9B3phND13
Resi9 biconnect 10000	10000	400 or 415	3P+N	16	D	10R9B3phND16
Resi9 biconnect 10000	10000	400 or 415	3P+N	20	D	10R9B3phND20
Resi9 biconnect 10000	10000	400 or 415	3P+N	25	D	10R9B3phND25
Resi9 biconnect 10000	10000	400 or 415	3P+N	32	D	10R9B3phND32
Resi9 biconnect 10000	10000	400 or 415	3P+N	40	D	10R9B3phND40
Resi9 biconnect 10000	6000	400 or 415	3P+N	50	D	10R9B3phND50
Resi9 biconnect 10000	6000	400 or 415	3P+N	63	D	10R9B3phND63
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	0.5	D	10R9B3phNRD0.5
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	0.75	D	10R9B3phNRD0.75
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	1	D	10R9B3phNRD1
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	2	D	10R9B3phNRD2
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	3	D	10R9B3phNRD3
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	4	D	10R9B3phNRD4
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	6	D	10R9B3phNRD6
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	8	D	10R9B3phNRD8
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	10	D	10R9B3phNRD10
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	13	D	10R9B3phNRD13
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	16	D	10R9B3phNRD16
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	20	D	10R9B3phNRD20
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	25	D	10R9B3phNRD25
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	32	D	10R9B3phNRD32
Resi9 biconnect 10000	10000	400 or 415	3P+N(*)	40	D	10R9B3phNRD40
Resi9 biconnect 10000	6000	400 or 415	3P+N(*)	50	D	10R9B3phNRD50
Resi9 biconnect 10000	6000	400 or 415	3P+N(*)	63	D	10R9B3phNRD63



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier COURTES
 Manager of Certification Operations



Resi9 biconnect 10000	10000	400 or 415	4P	0.5	D	10R9B4D0.5
Resi9 biconnect 10000	10000	400 or 415	4P	0.75	D	10R9B4D0.75
Resi9 biconnect 10000	10000	400 or 415	4P	1	D	10R9B4D1
Resi9 biconnect 10000	10000	400 or 415	4P	2	D	10R9B4D2
Resi9 biconnect 10000	10000	400 or 415	4P	3	D	10R9B4D3
Resi9 biconnect 10000	10000	400 or 415	4P	4	D	10R9B4D4
Resi9 biconnect 10000	10000	400 or 415	4P	6	D	10R9B4D6
Resi9 biconnect 10000	10000	400 or 415	4P	8	D	10R9B4D8
Resi9 biconnect 10000	10000	400 or 415	4P	10	D	10R9B4D10
Resi9 biconnect 10000	10000	400 or 415	4P	13	D	10R9B4D13
Resi9 biconnect 10000	10000	400 or 415	4P	16	D	10R9B4D16
Resi9 biconnect 10000	10000	400 or 415	4P	20	D	10R9B4D20
Resi9 biconnect 10000	10000	400 or 415	4P	25	D	10R9B4D25
Resi9 biconnect 10000	10000	400 or 415	4P	32	D	10R9B4D32
Resi9 biconnect 10000	10000	400 or 415	4P	40	D	10R9B4D40
Resi9 biconnect 10000	6000	400 or 415	4P	50	D	10R9B4D50
Resi9 biconnect 10000	6000	400 or 415	4P	63	D	10R9B4D63


(*) neutral pole on right



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier  Manager of Certification Operations



Rated operational voltage U_e : (V)	1P : 230 or 400 1P+N : 230 or 240 2P, 3P, 3P+N, 4P : 230,240,400 or 415
Rated current I_n : (A)	B : 1A to 63A C : 0.5A to 63A D : 0.5A to 63A
Rated frequency : (Hz)	50/60
Nature of supply :	~
Total number of poles :	1, 1+N (neutral on left), 2, 3, 3+N (neutral on left), 4
Number of protected poles :	all
Rated insulation voltage U_i : (V)	500
Rated impulse withstand voltage U_{imp} : (V)	4000
Instantaneous tripping current :	B : 1A to 63A C : 0,5 to 63A D : 0,5 to 63A
Reference ambient calibration air temperature : (°C)	30
Rated short-circuit capacity I_{cn} : (A)	10 000 : (1 to 63A) for B 10 000 : (0,5 to 63A) for C 10 000 : (0,5 to 40A) for D 6 000 : (50 and 63A) for D
Rated making and breaking capacity on one pole Separately - I_{cn1} : (A)	10 000 : (1 to 63A) for B 10 000 : (0,5 to 63A) for C 10 000 : (0,5 to 40A) for D 6 000 : (50 and 63A) for D
Energy limiting class (I^2t) : according to EN 60898-1	3 for B and C
Grid distance (short-circuit tests) :	45 mm (0,5A up to 25A) 55 mm (32A and 40A) 65 mm (50A and 63A)
Protection against external influences :	enclosed
Protection degree :	IP20
Material group :	II
Method of mounting :	panel board/distribution board, on rail
Method of electrical connection	not associated with the mechanical-mounting
Type of terminals :	pillar terminals
Nominal diameter of thread : (mm)	5,0 (0,5 up to 25A include) 6,5 (32A up to 63A)
Operating means	lever



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/02/2024

Signature: Didier BOURDES
Manager of CEI Safety Operations

