



Ref. Certif. No.

FR\_721224/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch for fixed electrical installation  
Switches for fixed-electrical installations

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS  
31 rue Pierre Mendes France, Eybens  
38050 GRENOBLE Cedex 9  
FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC BULGARIA EOOD  
Plovdiv plant  
4202 RADINOVO PLOVDIV  
BULGARIA

Name and address of the factory

SCHNEIDER ELECTRIC BULGARIA EOOD  
Plovdiv plant  
4202 RADINOVO PLOVDIV  
BULGARIA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Selector switches (Series Acti9)  
See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_721224 dated 11/03/2025. Change of manufacturer and factory

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

25685504-809956

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/05/2025

Signature:

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15,745,984 €  
RCS Nanterre B 468 362 172  
33 avenue du Général Leclerc  
F - 92266 FONTENAY-AUX-ROSES

Julien GAUTHIER  
Certification Officer

## ANNEX

### References, ratings and main characteristics:

References	Fonction Pattern number
A9E18070	6
A9E18071	6/2
A9E18072	1 NO 1 NC
A9E18073	4
A9E18074	4/2

Ouverture des contacts	normal gap
Protection degree	IP20
Method of actuating	tumbler
Method of mounting	in distribution boards on rail
Type of terminals	screw-type
Ratings	20A, 250V~



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/05/2025

Signature:



LABORATOIRE CENTRAL DES  
 INDUSTRIES ELECTRIQUES  
 S.A.S au capital de 15.745.984 €  
 RCS Nanterre B 399 033  
 33 avenue du Général Leclerc  
 92260 FONTENAY-AUX-ROSES

**Julien GAUTHIER**  
Certification Officer