

DC Wiring Diagram, PowerPacT™ H-J

Retain for future use.

Type	Ground Negative ¹	Grounded Middle Point	Ungrounded Source
	250 Vdc	≤ 250 Vdc	≤ 250 Vdc
2 P			
3 P			

¹ It is acceptable to ground the positive leg.

Circuit Breaker Specifications (UL® / CSA® / NOM®)	
Circuit Breaker Type	250 Vdc ²
D, G, J, L	20 kA

² 250 Vdc ratings only available with PowerPacT H or J circuit breakers with thermal-magnetic trip units (not including MCP.)

Schneider Electric USA, Inc.
 800 Federal Street
 Andover, MA 01810 USA
 888-778-2733
 www.se.com/us

Electrical equipment must be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

Schneider Electric and Square D are trademarks and the property of Schneider Electric SE, its subsidiaries, and affiliated companies. All other trademarks are the property of their respective owners.

