



# 中国国家强制性产品认证证书

证书编号: 2013010307592036

## 委托人名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产者(制造商)名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 生产企业名称、地址

上海施耐德工业控制有限公司  
上海市普陀区绥德路629号

## 产品名称和系列、规格、型号

电动机断路器

GZ1E; 详见参数附件

## 产品标准和技术要求

GB 14048.2-2008, GB 14048.4-2010

上述产品符合强制性产品认证实施规则  
CNCA-01C-012: 2007的要求, 特发此证。

发证日期: 2013年01月10日

有效期至: 2018年01月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0663783



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2013010307592036

## NAME AND ADDRESS OF THE APPLICANT

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Schneider Shanghai Industrial Control Co.,Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

## NAME, MODEL AND SPECIFICATION

Motor Circuit-breaker

GZ1E;See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008, GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-012:2007).

Date of issue: Jan.10,2013      Date of expiry: Jan.10,2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0663783



# 中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2013010307592036

纸号: 663783

GZ1E

$U_i=690V$ ;

$U_e: AC230/240V, AC400/415V, AC500V, AC690V$ ;

$I_n: 0.16A, 0.25A, 0.40A, 0.63A, 1A, 1.6A, 2.5A, 4A,$   
 $6.3A, 10A, 14A, 18A, 23A, 25A, 32A$ ;

过电流脱扣器类型: 热磁式;

$I_{cs}/I_{cu}$ :

AC230/240V:

23-32A: $I_{cs}=100\%I_{cu}, I_{cu}=30kA$ ;

0.16-18A: $I_{cs}=100\%I_{cu}, I_{cu}=100kA$ ;

AC400/415V:

23-32A: $I_{cs}=40\%I_{cu}, I_{cu}=10kA$ ;

14-18A: $I_{cs}=50\%I_{cu}, I_{cu}=10kA$ ;

0.16-10A: $I_{cs}=100\%I_{cu}, I_{cu}=100kA$ ;

AC500V:

23-32A: $I_{cs}=75\%I_{cu}, I_{cu}=3kA$ ;

14-18A: $I_{cs}=75\%I_{cu}, I_{cu}=5kA$ ;

10A: $I_{cs}=100\%I_{cu}, I_{cu}=8kA$ ;

6.3A: $I_{cs}=100\%I_{cu}, I_{cu}=30kA$ ;

0.16-4A: $I_{cs}=100\%I_{cu}, I_{cu}=100kA$ ;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心



中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2013010307592036

纸号: 663783

AC690V:

2.5-32A:Ics=75%Icu,Icu=2kA;

0.16-1.6A:Ics=100%Icu,Icu=100kA;

脱扣级别:10A; 使用类别 :A 类; 3P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2013010307592036

纸号: 663783

型号的解釋:

	<u>GZ1</u> I	<u>E</u> II	<u>01</u> II	<u>N</u> IV
I	产品基本型号 GZ1 电动机断路器			
II	操作器类型 E- 按钮操作 (热过载-短路保护)			
III	电流规格设定范围 01:0.10-0.16A 02:0.16-0.25A 03:0.25-0.40A 04:0.40-0.63A 05:0.63-1.0A 06:1.0-1.6A 07:1.6-2.5A 08:2.5-4.0A 10:4.0-6.3A 14:6-10A 16:9-14A 20:13-18A 21:17-23A 22:20-25A 32:24-32A			
IV	Options N:只在国内销售			

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2013010307592036

纸号: 663783

空白:中国制造 出口产品
--------------

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

