



Ref. Certif. No.

HU-003800

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Electronic over current relays
Name and address of the applicant	Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 31 Rue Pierre Mendés France 38050 GRENOBLE Cedex 09, France
Name and address of the factory	Schneider Electric Korea Ltd. 63-5 Seokam-ro 1-gil Iksan City, Jun Book, Republic of Korea
Ratings and principal characteristics	Rated op. voltage (Ue): 690 V Current range: 0,3 - 1,5 A; 1,2 - 7 A; 5 - 25 A; 20 - 38 A Rated impulse withstand voltage Uimp (kV): 6 kV Utilization category: AC-15 / DC-13 (For further details see CB Test Report)
Trademark (if any)	Schneider
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LR97Dxyz; where x means current range, can be: 015; 07; 25; 38 y means control voltage, can be: B; E; F7; M7 z means voltage, can be: void; S185; S189 (For detailed type nomenclature see CB Test Report)
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018 IEC 60947-5-1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	HU21ISYU 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2022-04-25

Signature:

  
Tamás László Tötös