



# Certificate of Compliance

**Certificate:** 2697001

**Master Contract:** 260142

**Project:** 2697001

**Date Issued:** January 24, 2014

**Issued to:** Telemecanique/Schneider Electric Industries SAS  
BP 660  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
FRANCE  
**Attention:** Mr. Jean-Pierre Laidet

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Anne Drouin  
Anne Drouin

## PRODUCTS

CLASS – 3211 07 INDUSTRIAL CONTROL EQUIPMENT Miscellaneous Apparatus

Relays, component, open type, magnetically operated, single-pole, RSL Series, electrical ratings as follows:

Model: RSL1JB4BD

Contact	A	HP	Vac	Vdc	Use	°C	Cycles	Material	Pilot Duty
NO	6	--	277	--	Gen.	85	20 k	AgSnO2	B300, R300 at 85°C, 6 k cycles, or C300, R300 at room temperature 30k cycles
	6	--	277	--	Resistive	85	60 k	AgSnO2	
	6	--	--	30	--	85	60 k	AgSnO2	



**Certificate:** 2697001

**Project:** 2697001

**Master Contract:** 260142

**Date Issued:** January 24, 2014

Models: RSL1AB4BD, RSL1AB4ED, RSL1AB4JD, RSL1AB4ND, RSL1GB4BD, RSL1GB4ED, RSL1GB4JD, RSL1GB4ND.

Contact	A	HP	Vac	Vdc	Use	°C	Cycles	Material	Pilot Duty
NO	6	--	277	--	Gen.	85	20 k	AgSnO2	B300, R300 @ 85°C, 6 k cycles, or C300, R300 at room temperature 30 k cycles
	6	--	277	--	Resistive	85	30 k	AgSnO2	
	6	--	--	30	--	85	30 k	AgSnO2	
NC	6	--	277	--	Gen.	85	10 k	AgSnO2	B300, R300 @ 85°C 6 k cycles
	6	--	--	30	--	85	10 k	AgSnO2	

Coil: 3 – 60 VDC at surrounding air temperature 85 °C.

Notes:

- These units are open-type devices and certified only for use in complete assemblies where the suitability of the combination is to be determined.

**MARKINGS**

Company's name, and/or CSA file number 260142, type designation, electrical ratings, serial number or date coding, the CSA Mark appear in a permanent manner on each unit, and any other information as specified in the Certification Report.