

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Anti-Tripping Module 3P
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier, 92500 Rueil-Malmaison France
Name and address of the manufacturer	Schneider Electric Industries SAS 31, rue Pierre Mendès, 38320 Eybens France
Name and address of the factory	Wanbang Digital Energy Co., Ltd. No.39 Longhui Road, Wujin High-tech Zone, 213000 Changzhou Jiangsu China
<i>When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	<b>Product data</b> Ratings: AC 220/230/240 V(L-N), 50/60 Hz, ≤5 W, 3P4W
Trademark / Brand (if any)	 Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	EVA1HPC3 and EVA2HPC3
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010 and IEC 61010-1:2010/AMD1:2016  National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6172217.50(A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 30 October 2023

  
Signature: K Xu