

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Auxiliary switches to be mounted on VN12, VN20, VCDN12, VCDN20 VCCDN12, VCCDN20, VBDN12, VBDN20 (3-pole switch-disconnectors)
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier, 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 35 Rue Joseph Monier, 92500 Rueil-Malmaison, France
Name and address of the factory	Schneider Electric A.S. Cizovska 447, 397 01 Pisek, Czech Republic
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	<b>Product data</b> Ratings: $U_i = 690\text{ V}$ , $U_{imp} = 6\text{ kV}$ , $I_{th} = 12\text{ A}$ AC-15: 6 A at 240 Vac, 4 A at 415 Vac, 2 A at 500 Vac, 1 A at 690 Vac
Trademark / Brand (if any)	SCHNEIDER ELECTRIC
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	VZN05 (NO contact) and VZN06 (NC contact)
Additional information	<input checked="" type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2024 and IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	3334987.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 2025-10-10

Signature: A. Manokaran

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## Additional information

This certificate replaces CB certificate No. NL-56840/A1 issued on 2020-06-04.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands



Date: 2025-10-10

Signature: A. Manokaran