

NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- ⚠ OVERALL CONTAINMENT HEIGHT DIMENSION MAY VARY AS PER THE RACK SELECTED.
 - 48U HEIGHT RACK SHOWN FOR TYPICAL ARRANGEMENT. UP TO 52U HEIGHT CAN BE ACCOMMODATED.
 - TWO HEIGHT ADAPTERS ARE REQUIRED FOR 52U RACKS. REFER TO TABLE FOR DETAILS.
- THIS DIMENSION MAY VARY AS PER THE DEPTH OF THE RACK SELECTED. 1070 [42.13] DEPTH RACK SHOWN FOR TYPICAL ARRANGEMENT
- 6. THIS DRAWING IS FOR TYPICAL CONFIGURATION.


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:
NetShelter Aisle CONTAINMENT Gen 2 DUAL ROW CEILING, ENCLOSURE MOUNTED WITH 20 RACKS PER ROW
FRONT VIFW

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3 APPROVED BYPankaj GHADGE 28-MAR-24

DWG NO: NSACDRDDC40RACKS		REV.	
DRAWN BY:	JAYAPRAKASH	28-MAR-24	FIR
ENGINEER:	Jigho He	28-MAR-24	ANG



RIGHT SIDE VIEW

NOIFS

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- 4. WEIGHT REFER TO THE RESPECTIVE SUBMITTALS.

THIS DIMENSION MAY VARY AS PER RACK WIDTH AND NUMBER OF RACKS. SHOWN TYPICAL ARRANGEMENT FOR 20 RACKS/ROW OF 600mm WIDE.

SHOWN TYPICAL ARRANGEMENT FOR 48U RACKS.

7. THIS DRAWING IS FOR TYPICAL CONFIGURATION.


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



	TITLE:
	NetShelter Aisle CONTAINMENT Gen 2
	DUAL ROW CEILING, ENCLOSURE MOUNTED
•	WITH 20 RACKS PER ROW
.	RIGHT SIDE VIEW

`	DWG NO: NSACDRDDC40RACKS			REV.
	DRAWN BY:	JAYAPRAKASH	28-MAR-24	FIRST
	ENGINEER:	liaho Ho	28_MAR_24	ANGLE

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3 APPROVED BYPANKAJ GHADGE 28-MAR-24





AISLE V	WIDTH
Feet	mm
~3	972
~4	1268
~6	1860

NOTES

- 1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

ACROSS AISLE DIMENSION MAY VARY AS PER THE REQUIREMENT.
TABLE SHOWS STANDARD CONFIGURATION.

PANEL IS TO BE CUT TO MATCH THE WIDTH FOR DIMENSIONS OTHER THAN ${\sim}4$ FEET & ${\sim}6$ FEET.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



	TITLE:
	NetShelter Aisle CONTAINMENT Gen 2
,	DUAL ROW CEILING, ENCLOSURE MOUNTED
	WITH 20 RACKS PER ROW
Ü	TOP VIEW

	DWG NO: NSACDRDDC40RACKS			REV.
)	DRAWN BY	: JAYAPRAKASH	28-MAR-24	FIRST

PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 3 APPROVED BYPANKA GHADGE 28-MAR-24 PROJECT