



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230306008132

Product	Control Switch
Applicant	Schneider Shanghai Low Voltage Terminal Apparatus Co.,Ltd. No.1319 Ping'an Road, Minhang District,Shanghai, P.R.China
Type/Model	OF,SD,OF+SD/OF;
Technical data	See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 02402-23119Y29037, the submitted sample(s) of the above item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jul.31,2023

Valid until: Apr.09,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230306008132

OF,SD,OF+SD/OF;

Ui:415V;Uimp:4kV;


Ith:6A;

Ue/le:

AC-12:AC415V/3A;AC240V/6A;

DC-12:DC130V/1A;DC48V/2A;DC24V/6A;

IP20



CHINA QUALITY CERTIFICATION CENTRE