


No. P22226523

Applicant	ELKO AS Sandstuveien 68 Oslo 0680 Norway		
Manufacturer	ELKO AS Sandstuveien 68 Oslo 0680 Norway		
Factory	CTM Lyng AS Verkstedvegen 19 Vanvikan 7125 Norway		
Project Number	PRJ0018944		
Product	Termostat		
Model/Type Ref.	TERMOSTAT SUPER TR		
Ratings	10A 230V AC 50Hz		
Trademark	ELKO		
Principal Characteristics	Cl. II IP20, Room thermostat, for flush mounting, Two pole, Type 1.B action, pollution degree 2, overvoltage category III, PTI 175, Screw terminals pillar type, with internal sensor and/or external floor sensor		
A sample of the product was tested and found to be in conformity with	<table><tr><td>Safety</td><td>EN 60730-1:2016;A1 EN IEC 60730-2-9:2019;A1;A2</td></tr></table>	Safety	EN 60730-1:2016;A1 EN IEC 60730-2-9:2019;A1;A2
Safety	EN 60730-1:2016;A1 EN IEC 60730-2-9:2019;A1;A2		
Validity	<p>This certificate documents conformity with the standards shown, and also applies as license for use of Nemko's name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation.</p> <p>New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.</p>		
Additional Information			
Additional model(s)	(1) See page 2		

Jiyea Gim

Jiyea Gim
Certification Department
11 / 11 / 2022



www.nemko.com

Page 1 of 2

Signature

Date of issue




CERTIFICATE

No. P22226523



Product	Thermostat
Variant No.	1
Model/Type Ref.	TERMOSTAT SUPER TR RF
Ratings	10A 230V AC 50Hz
Trademark (if different from page 1)	
Principal Characteristics	Cl. II IP20, Room thermostat, for flush mounting, Two pole, Type 1.B action, pollution degree 2, overvoltage category III, PTI 175, pillar terminals, with internal sensor and/or external floor sensor. A Zigbee Radio 2405-2480MHz is build-in

Jiyea Gim



www.nemko.com

Signature

Jiyea Gim

Date of issue

Certification Department

11 / 11 / 2022

Page 2 of 2

Working for a more sustainable future- Please do not print