

## Certificate of Conformity

 $( \bullet )$ 

Number NMi-CoC-24.12 Project number 3195407 Page 1 of 3

Issued by	:	NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands		
Applicant	:	Schneider Electric Canada 2195 Keating Cross Road Saanichton, BC V8M 2A5 Canada	a li	nc.
Submitted	:	Static electrical energy	'n	neter
		Manufacturer : Type : Destined for the : measurement of		Schneider Electric PowerLogic PM8000 (METSEPM 8xxx) Electrical active / reactive energy in a - three-phase four-wire network - three-phase three-wire network
In accordance with	:	See page 2		
Characteristics	:	See page 3		

The undersigned declares that the described product is tested according to the standards as referred to on page 2 and meet their requirements, based on a non-recurrent examination. The appertaining test data is presented in the type evaluation reports NMi-3195407-01, NMi-3195407-02, NMi-3195407-03, NMi-3195407-04, NMi-3600522-01, NMi-2528595-01b and NMi-2553437-02 issued by NMi, and including external test reports 12046-1E and 16741-1E issued by LabTest Certification Inc, Canada and E189364-D1000-1/A3/C2-CB issued by UL.

NMi Certin B.V. 26 March 2024

**Certification Board** 

Ŧ

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the applicant shall indemnit third-party liability.

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signatur can be verified in the blue ribbon at the top of the electronic version of this certificate.





## Certificate of Conformity

 $( \bullet )$ 

Number NMi-CoC-24.12 Project number 3195407 Page 2 of 3

### IEC 62052-11: 2020

"Electricity metering equipment - General requirements, tests and test conditions - Part 11: Metering equipment"

#### IEC 62053-22: 2020

"Electricity metering equipment - Particular requirements - Part 22: Static meters for AC active energy (classes 0,1 S, 0,2 S and 0,5 S)"

#### IEC 62053-24: 2020

"Electricity metering equipment - Particular requirements - Part 24: Static meters for fundamental component reactive energy (classes 0,5S, 1S, 1, 2 and 3)"

#### IEC 62052-31: 2015

"Electricity metering equipment (AC)-General requirements, tests and test conditions- Part 31: Product safety requirements and tests"

### IEC 61000-4-19: 2014

"Electromagnetic compatibility (EMC) - Part 4-19: Testing and measurement techniques - Test for immunity to conducted, differential mode disturbances and signalling in the frequency range 2 kHz to 150 kHz at a.c. power ports";



# Certificate of Conformity

Number NMi-CoC-24.12 Project number 3195407 Page 3 of 3

Characteristics of the measuring instrument				
Model	PM8000 (METSEPM 8xxx)			
Accuracy class	0,2S for active energy (IEC 62053-22) 0,5S for reactive energy (IEC 62053-24)			
Destined for the measurement of	electrical energy, in a - three-phase four-wire network - three-phase three-wire network			
U <sub>n-min</sub> U <sub>n-max</sub>	3 x 57/ 100 V 3 x 400/ 690 V			
In	5 A			
I <sub>max</sub>	10 A			
f <sub>ref</sub>	50 and 60 Hz			
Relevant product standards	IEC 62052-31:2015			
Classification of installation and use	OVC III / CAT III			
Environmental conditions	Operation: -25 °C +70 °CStorage: -40 °C +85 °CAltitude: up to 3000 mPollution degree: 2 (indoor)Location: dry			
Degree of protection	IP 54 (Panel mount and Remote display, front)			
Protective class	11			
Rated impulse voltage	Up to 6 kV (BI) or 8kV (RI/DI)			
Software version	004.xxx.xxx, with x being any number			
Hardware version	IO board: MFR3370329 CVM board: MFR3370629 PSU board: MFR3370429 PSU LV-DC-DC board: QGH244130			
Aux Power supply				
AC/DC Power supply	90 - 415 VAC / 110 - 415 VDC			
LV DC Power supply	20 – 60 VDC			
Rated Frequency	50/60 Hz			