



02 March 2020

33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

Schneider Electric (Australia) Pty. Ltd.

Attention: Samuel Lee

Dear Sir / Madam,

### **APPROVAL OF PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Office of the Technical Regulator.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact George Nestic on telephone ,or email [george.nestic@sa.gov.au](mailto:george.nestic@sa.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Office of the Technical Regulator of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in blue ink that reads "George Nestic".

**AUTHORISED OFFICER**

Ref: OTR200078/00



Certificate Number: OTR200078/00



# Certificate of Approval

This is to certify that the Authorised officer has approved the electrical equipment described hereunder.

**Registered Declarant:** Schneider Electric (Australia) Pty. Ltd.  
33-37 Port Wakefield Road, Gepps Cross SA 5094, Australia

## Required Marking: OTR200078

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Office of the Technical Regulator prior to the equipment being supplied or offered for supply.

Notification must be given to Office of the Technical Regulator of any change to the name or address of the holder of the certificate within 20 business days.

### ARTICLE DETAILS

Electrical Equipment:	Level 3 Residual Current Device Residual Current Device and Arc Fault Detection Device
Relevant Standards:	AS/NZS 61009.1:2015 + IEC 62606:2013 + A1:2017
Expiry Date:	02 March 2025
Conditions of Approval:	

A handwritten signature in blue ink, appearing to read 'George Neill'.



Certificate Number: OTR200078/00



## Approval details

Model	4AFRC206
Rated at	Input: 230/240 Vac, 6 A
Trade Name	CLIPSAL
Comments	Icn = 6kA

Model	A9T26606
Rated at	Input: 230/240 Vac, 6 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 6kA

Model	4AFRC210
Rated at	Input: 230/240 Vac, 10 A
Trade Name	CLIPSAL
Comments	Icn = 6kA

Model	A9T26610
Rated at	Input: 230/240 Vac, 10 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 6kA

Model	4AFRC216
Rated at	Input: 230/240 Vac, 16 A
Trade Name	CLIPSAL
Comments	Icn = 6kA

Model	A9T26616
Rated at	Input: 230/240 Vac, 16 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 6kA

A handwritten signature in blue ink, appearing to read "George Neill".



Certificate Number: OTR200078/00



Model	4AFRC220
Rated at	Input: 230/240 Vac, 20 A
Trade Name	CLIPSAL
Comments	Icn = 6kA

Model	A9T26620
Rated at	Input: 230/240 Vac, 20 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 6kA

Model	4AFRC225
Rated at	Input: 230/240 Vac, 25 A
Trade Name	CLIPSAL
Comments	Icn = 6kA

Model	A9T26625
Rated at	Input: 230/240 Vac, 25 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 6kA

Model	A9T27606
Rated at	Input: 230/240 Vac, 6 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 10kA

Model	A9T27610
Rated at	Input: 230/240 Vac, 10 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 10kA

Model	A9T27616
Rated at	Input: 230/240 Vac, 16 A

A handwritten signature in blue ink, appearing to read "George Neill".

Certificate Number: OTR200078/00



Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 10kA

Model	A9T27620
Rated at	Input: 230/240 Vac, 20 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 10kA

Model	A9T27625
Rated at	Input: 230/240 Vac, 25 A
Trade Name	SCHNEIDER ELECTRIC
Comments	Icn = 10kA

A handwritten signature in blue ink that reads "George Neill".

