



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100799

Socket-outlet

Type designation: NU-037--, NU-057--, NU-066--, NU-067--A, NU-067--AS, NU-076--

Certificate holder: Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
FRANCE

The product complies with the standard(s): IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+R1+T1
NEK 502:2016

Date of expiry: 27 September, 2024

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm


Signed:  **Date:** 03 June, 2021


Quan Li


APPENDIX:


Reference No. SE-S-2100799

Technical Data:

Type designation NU-037--
Rated voltage (V) 250 VAC
Rated current (A) 16A
IP-Class 20
Standard sheet III
Trademark 
Test Report 1911208STO-001, 17PS061A3, 2010060STO-001
Product information Single socket-outlet, screw terminals, with shutters. With cover NVE6545702 to be assembled with accessories.


Type designation NU-057--
Rated voltage (V) 250 VAC
Rated current (A) 16A
IP-Class 20
Standard sheet III
Trademark 
Test Report 1911208STO-001, 17PS061A9, 2028035STO-001
Product information Single socket-outlet, screw-less terminals, with shutters. With cover NVE6545702 to be assembled with accessories.


Type designation NU-066--
Rated voltage (V) 250 VAC
Rated current (A) 16A
IP-Class 20
Standard sheet III
Trademark 
Test Report 2010060STO-001, 19PS081A2, 2028035STO-001
Product information Double socket-outlet, screw-less terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

Type designation NU-067--A
Rated voltage (V) 250 VAC
Rated current (A) 16A
IP-Class 20
Standard sheet III
Trademark 
Test Report 1911208STO-001, CEL-0043/18-1
Product information Double socket-outlet, screw terminals and insulating piercing terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

APPENDIX:

Reference No. SE-S-2100799

<i>Type designation</i>	NU-067--AS
<i>Rated voltage (V)</i>	250 VAC
<i>Rated current (A)</i>	16A
<i>IP-Class</i>	20
<i>Standard sheet</i>	III
<i>Trademark</i>	
<i>Test Report</i>	1911208STO-002, CEL-0082/18-1
<i>Product information</i>	Double socket-outlet with signal lamp, screw terminals and insulating piercing terminals, with shutters. With cover NVE6925502 to be assembled with accessories.

<i>Type designation</i>	NU-076--
<i>Rated voltage (V)</i>	250 VAC
<i>Rated current (A)</i>	16A
<i>IP-Class</i>	20
<i>Standard sheet</i>	III
<i>Trademark</i>	
<i>Test Report</i>	2010060STO-001, 19PS081A3, 2028035STO-001
<i>Product information</i>	Triple socket-outlet screw-less terminals, with shutters. With cover MFR3955102 to be assembled with accessories.

Accessory Cover-plates:

NU2002--, NU2004--, NU2006--, NU2008--, NU2010--, NU2102--, NU2103--, NU2104--,
 NU4002--, NU4004--, NU4006--, NU4008--, NU4110--, NU4114--, NU4116--, NU4118--,
 NU6002--, NU6004--, NU6004V--, NU6006--, NU6008—

Accessory Supporting frames:

NU7002, NU7002P, NU7004PC, NU7006C, NU7008C,
 NU7103, NU7103P, NU7104, NU7892, NVE6944902

Accessories intended for floor, desk, service pole, service post and other similar non flush wall installations.

Type NU-067--A and NU-067--AS are not applicable for Norway.


Accessory Cover-Plates and Accessory Supporting Frames are not applicable for Norway.

APPENDIX:

Reference No. SE-S-2100799

Manufacturing Sites: Schneider Electric Espana S.A.
Ctra. Pamplona-Logroño, s/n
31100 Puente la Reina (Navarra)
SPAIN

This certificate replaces previously issued ref. No. SE-S-2001343 dated 16 April 2020.



Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 03 June, 2021

Quan Li