

  
Intertek **CERTIFICATE**  
**FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2101450

## Wall box for electrical installation

**Type designation:** 100991

**Certificate holder:** Schneider Electric Industries SAS  
35 rue Joseph Monier  
Rueil-Malmaison 92500, France

**The product complies with the standard(s):** EN IEC 60670-1:2021+A11

**Date of expiry:** 29 October, 2026

**EU Directive information:** According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 29 October, 2021


Quan Li

**Intertek**

## APPENDIX:

Reference No. SE-S-2101450

### Technical Data:

*Type designation* 100991  
*Trademark*   
*Test Report* 2108941STO-001  
*Product information* Special Central/Tele flush box of insulation material. For mounting behind electrical distribution board.  
With inlets for 16, 20, 25, 32, and 50 mm conduits.  
Temperature range -25/+90°C.  
Insulation material: no halogens according EN 60754-2:2014.


### Manufacturing Sites:

Elda-Eltra Elektrotechnika S.A.  
ul. Bugno 1  
Szczecinek 78-400  
Poland

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 29 October, 2021

Quan Li

**Intertek**