



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200152

Thermostat

Type designation:

STR-16

Certificate holder:

Schneider Electric Industries SAS
35 rue Joseph Monier,
92500 Rueil-Malmaison, France

The product complies with the standard(s):

EN 60730-1:2016+A1:2019,
EN IEC 60730-2-9:2019+A1+A2

Date of expiry:

25 January, 2027

EU Directive information:

According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Intertek

Additional information in Appendix

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:

Date:

08 February, 2022

Leif Mattsson

APPENDIX:

Reference No. SE-S-2200152

Technical Data:

Type designation	STR-16
Rated voltage (V)	230 VAC
Rated current (A)	16 A
Frequency (Hz)	50 Hz
Class	II
IP-Class	IP20
Trademark	Schneider Electric
Test Report	HELES2110001059-1
Product information	Relay: 1E5 micro-disconnection Switch: 5E4 full-disconnection Features of automatic action: Type 1 Construction: For flush mounting For use in normal pollution situations Resistance to heat and fire: Category D 10T30 PTI250

Manufacturing Sites:

Lexel Fabrika, SIA
Krustpils 35a
LV-1073, Riga, Latvia

According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate is based on a certificate with ref. No. FI/41296 dated 25 January 2022, issued by SGS Fimko according to the Nordic Certification Service Agreement.

This certificate replaces the S certificate SE-S-2001701 dated 11 June 2020 due to new testing.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 08 February, 2022

Leif Mattsson