



# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200472

### Thermostat

**Type designation:** STR-10

**Certificate holder:** Schneider Electric Industries SAS  
35 rue Joseph Monier  
92500 Rueil-Malmaison, France

**The product complies with the standard(s):** EN 60730-1:2016+A1:2019  
EN IEC 60730-2-9:2019+A1+A2

**Date of expiry:** 07 April, 2027

**EU Directive information:** According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**

**Date:** 14 April, 2022

Henrik Wikström

## APPENDIX:

Reference No. SE-S-2200472

### Technical Data:

Type designation	STR-10
Rated voltage (V)	230 V~
Rated current (A)	10 A
Frequency (Hz)	50 Hz
Class	II
IP-Class	IP20
Trademark	Schneider Electric
Test Report	HELES2110001057-1
Product information	Relay: 1E5 micro-disconnection Switch: 5E4 full-disconnection Features of automatic action: Type 1 Construction: For flush mounting For use in normal pollution situations Resistance to heat and fire: Category D 10T30 PTI250

### Manufacturing Sites:

Lexel Fabrika, SIA  
Krustpils 35a  
LV-1073, Riga, Latvia

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate is based on a certificate with Ref. No. FI/41359 dated 2022-04-07 issued by SGS Fimko Ltd according to the Nordic Certification Service agreement.

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 14 April, 2022

Henrik Wikström