



# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2201029

### Circular box for electrical installation with suspension means

**Type designation:** 350219, 350220, 350221

**Certificate holder:** Schneider Electric Industries SAS  
35 rue Joseph Monier  
92500 Rueil-Malmaison  
France

**The product complies with  
the standard(s):** EN IEC 60670-1:2021+A11


**Date of expiry:** 14 September, 2027

**EU Directive information:** According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

**Intertek**

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 14 September, 2022

Leif Mattsson

## APPENDIX:

Reference No. SE-S-2201029

### Technical Data:

Type designation 350219, 350220, 350221  
Standard sheet SS 4300619  
Trademark



Test Report 2205000STO-001

Product information Circular flush connecting box (hollow wall and ceiling mounting, 13-40 mm wall and ceiling plate) of green, red and blue insulation material and metal fastening device, for luminaries. With 8 inlets for 16 mm conduits, 2 inlets for 20 mm conduits and 2 knock-outs at the bottom.

Temperature range -25/+90°C.

350219: green, mounting depth 13 mm

350220: red, mounting depth 26 mm

350221: blue, mounting depth 40 mm or 52,5 (with additional extension ring)

No halogen according to EN 60754-2:2014.

### Manufacturing Sites:

Tarnwell Polska sp. Z o.o.  
Ul. Wieslawa Wody 26, 33-100 Tarnow  
Poland

Elda-Eltra Elektrotechnika S.A.  
ul. Bugno 1, 78-400 Szczecinek  
Poland

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

### Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

### Signed:

Date: 14 September, 2022

Leif Mattsson