


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300770

Two-pole socket-outlet without earthing contact

Type designation: L3380 Catalogue ID: S-1012 PT

Certificate holder: Elko AS
Sandstuveien 68
0680 Oslo
NORWAY

**The product complies with
the standard(s):** IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1

Date of expiry: 18 July, 2028

Intertek

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 18 July, 2023

Quan Li

APPENDIX:

Reference No. SE-S-2300770

Technical Data:

Type designation L3380 Catalogue ID: S-1012 PT
Rated voltage (V) 250V AC
Rated current (A) 16 A
Trademark ELKO
Test Report Ref REP012491
Product information Socket-outlet for fixed installation. Standard Sheet I. Thermoplastic, flush mounting, single, with shutters and screw terminals, IP20, 60mm fixing distance

Manufacturing Sites:

Merten GmbH
Fritz-Kotz-Strasse 8
51674 Wiehl
GERMANY

This certificate is based on a certificate with ref. No. P23227119 dated 2023-06-29, issued by Nemko Group AS according to the Nordic Certification Service Agreement.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 18 July, 2023

Quan Li