



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2401157

Junction box

Type designation:

TED-012

Certificate holder:

Schneider Electric Industries SAS
35 rue Joseph Monier
Rueil-Malmaison 92500
France

The product complies with the standard(s):

EN IEC 60670-1:2021 + A11
EN 60670-22:2006+A1+A11

Date of expiry:

31 October, 2029

EU Directive information:

The product listed has been evaluated by a Third Party Body and deemed to meet the listed standard(s). This Certificate can be used in support of a claim in meeting relevant EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Additional information in Appendix

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:

Date:

31 October, 2024

Anneli Averland Johansson

APPENDIX:

Reference No. SE-S-2401157

Technical Data:

Type designation	TED-012
Rated voltage (V)	440V
IP-Class	IP54
Conductor area	2,5 - 6 mm ²
Trademark	THORSMANS
Test Report	2405559STO-001, 2405559STO-002
Product information	Thermoplastic connection box in all colours for surface mounting. For flouting terminals. With 10 inlets for membranes. Temperature range -25/+60°C. Impact 1J. With screw terminal type KP18, 6 mm ² or screwless terminal type SLDK2 PIN, 2,5 mm ² . With and without cable anchorage.

Manufacturing Sites:

Schneider Electric Elda S. A.
ul. Bugno 1
Szczecinek 78-400
Poland

This certificate replaces previously issued ref. No 1221378 dated 23 October 2012.
A new certificate has been issued due to full testing and update of standards.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 31 October, 2024

Anneli Averland Johansson