

Schneider Electric Security Notification

Web Server on Modicon M340, Legacy Offers Modicon Quantum and Premium and Associated Communication Modules

14 September 2021 (14 February 2023)

Overview

Schneider Electric is aware of multiple vulnerabilities in the web server component of the Modicon M340 PLC. In addition, the Modicon Quantum and Modicon Premium Legacy offers, and associated communication modules are affected.

The [Modicon Ethernet Programmable Automation](#) products are controllers for industrial process and infrastructure.

Failure to apply the remediations provided below may risk an attack via the web server, which could result in disclosure of sensitive information or denial of service of the controller.

February 2023 Update: A remediation is available for Modicon M340 Ethernet Communication Modules BMXNOE0100 (H) and BMXNOE0110 (H) ([page 4](#)).

Affected Products and Versions

Product	Version
Modicon M340 CPUs	BMXP34* versions Prior to V3.40
Modicon Ethernet Communication Modules	BMXNOE0100 (H) versions Prior to SV03.50 BMXNOE0110 (H) versions Prior to SV06.70 BMXNOC0401 versions Prior to V2.11 BMXNOR0200H RTU versions Prior to V1.7 IR24
Modicon Premium processors with integrated Ethernet COPRO	TSXP574634 All versions TSXP575634 All versions TSXP576634 All versions
Modicon Quantum processors with integrated Ethernet COPRO	140CPU65xxxxx All versions
Modicon Quantum communication Modules	140NOE771x1 All versions 140NOC78x00 All versions 140NOC77101 All versions
Modicon Premium communication Modules	TSXETY4103 All versions TSXETY5103 All versions

Schneider Electric Security Notification

Vulnerability Details

CVE ID: **CVE-2021-22785**

CVSS v3.1 Base Score 7.5 | High | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:H/I:N/A:N

A *CWE-200: Information Exposure* vulnerability exists that could cause sensitive information of files located in the web root directory to leak when an attacker sends a HTTP request to the web server of the device.

CVE ID: **CVE-2021-22788**

CVSS v3.1 Base Score 7.5 | High | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H

A *CWE-787: Out-of-bounds Write* vulnerability exists that could cause denial of service when an attacker sends a specially crafted HTTP request to the web server of the device.

CVE ID: **CVE-2021-22787**

CVSS v3.1 Base Score 7.5 | High | CVSS:3.0/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H

A *CWE-20: Improper Input Validation* vulnerability exists that could cause denial of service of the device when an attacker sends a specially crafted HTTP request to the web server of the device.

Remediation & Mitigation

Schneider Electric encourages all industrial companies to ensure they have implemented cybersecurity best practices across their operations and supply chains to reduce cyber risks. Where appropriate this includes locating industrial systems and remotely accessible devices behind firewalls; installing physical controls to prevent unauthorized access; preventing mission critical systems and devices from being accessed from outside networks; systematically applying security patches. In addition, specific recommended actions on the impacted products are listed below.

Affected Product & Version	Remediation/Mitigation
Modicon M340 CPU BMXP34* Prior to V3.40	V3.40 includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMXP34xxxx_SV_xx.xx/

Schneider Electric Security Notification

<p>Modicon M340 X80 Ethernet Communication Modules BMXNOR0200H RTU <i>Prior to V1.70 IR24</i></p>	<p>V1.70 IR24 includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMXNOR0200H_FW/</p> <p>Note: V1.70 IR23 previously included a fix for CVE-2021-22785</p> <p>If customers choose not to apply the recommended fixes, then they should apply the mitigations below to reduce the risk of the exploit:</p> <ul style="list-style-type: none"> • Setup network segmentation and implement a firewall to block all unauthorized access to port 80/HTTP (Note HTTP is disabled by default). • Configure the Access Control List following the recommendations of the user manual “Modicon M340 for Ethernet Communications Modules and Processors User Manual” in chapter “Messaging Configuration Parameters”: https://www.se.com/ww/en/download/document/31007131K01000/ • Setup a VPN between the Modicon PLC impacted modules and the engineering workstation containing EcoStruxure Control Expert or Process Expert.
<p>Modicon M340 Ethernet Communication Modules BMXNOE0100 (H) <i>Versions Prior to SV03.50</i> BMXNOE0110 (H) <i>Versions Prior to SV06.70</i></p>	<p>Version SV03.50 of BMXNOE0100 (H) includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMXNOE0100_SV_03.50/</p> <p>Version SV06.70 of BMXNOE0110 (H) includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMXNOE0110_SV_06.70/</p> <p>If customers choose not to apply the remediation, then they should immediately apply the following mitigations to reduce the risk of exploit:</p> <ul style="list-style-type: none"> • Setup network segmentation and implement a firewall to block all unauthorized access to port 80/HTTP (Note HTTP is disabled by default). • Configure the Access Control List following the recommendations of the user manual “Modicon M340 for Ethernet Communications Modules and Processors User Manual” in chapter “Messaging Configuration Parameters”: https://www.se.com/ww/en/download/document/31007131K01000/ • Setup a VPN between the Modicon PLC impacted modules and the engineering workstation containing EcoStruxure Control Expert or Process Expert.

Schneider Electric Security Notification

<p>Modicon M340 Ethernet TCP/IP Network Module BMXNOC0401 <i>Prior to V2.11</i></p>	<p>BMXNOC0401 V2.11 is available for download that has a fix of the reported vulnerabilities: https://www.se.com/ww/en/product/BMXNOC0401/ethernet-tcp-ip-network-module-modicon-m340-automation-platform-4-x-rj45-10-100/</p> <p>If customers choose not to apply the fix, then, they should immediately apply the following mitigations to reduce the risk of exploit:</p> <ul style="list-style-type: none"> • Setup network segmentation and implement a firewall to block all unauthorized access to port 80/HTTP • Setup a VPN between the Modicon PLC impacted modules and the engineering workstation containing EcoStruxure Control Expert or Process Expert.
<p>Modicon Quantum Processors with Integrated Ethernet COPRO 140CPU65xxxx <i>All versions</i></p>	<p>Modicon Quantum and Associated Communication Modules: Schneider Electric’s Modicon Quantum controllers have reached their end of life and are no longer commercially available. They have been replaced by the Modicon M580 ePAC controller, our most current product offer. Customers should strongly consider migrating to the Modicon M580 ePAC. Please contact your local Schneider Electric technical support for more information.</p> <p>To mitigate the risks, users should immediately:</p> <ul style="list-style-type: none"> • Disable the Web server using 'Web Access (HTTP)' via UnityPro / EcoStruxure Control Expert using the following guideline “Quantum using EcoStruxure™ Control Expert - TCP/IP Configuration, User Manual” in the chapter “Security (Enable / Disable HTTP, FTP, and TFTP)”: https://www.se.com/ww/en/download/document/33002479K01000
<p>Modicon Quantum Communication Modules: 140NOC78x00 <i>All versions</i> 140NOC77101 <i>All versions</i> 140NOE771x1 <i>All versions</i></p>	
<p>Modicon Premium processors with integrated Ethernet COPRO: TSXP574634 <i>All versions</i> TSXP575634 <i>All versions</i> TSXP576634 <i>All versions</i></p>	<p>Modicon Premium and Associated Communication Modules: Schneider Electric’s Modicon Premium controllers have reached their end of life and are no longer commercially available. They have been replaced by the Modicon M580 ePAC controller, our most current product offer. Customers should strongly consider migrating to the Modicon M580 ePAC. Please contact your local Schneider Electric technical support for more information.</p> <p>To mitigate the risks, users should immediately:</p> <ul style="list-style-type: none"> • Disable the Web server using 'Web Access (HTTP)' via UnityPro / EcoStruxure Control Expert using the following guideline “Premium and Atrium using EcoStruxure™ Control Expert - Ethernet Network Modules, User Manual” in the

Schneider Electric Security Notification

<p>Modicon Premium Communication Modules: TSXETY4103 <i>All versions</i> TSXETY5103 <i>All versions</i></p>	<p>chapter “Security Service Configuration Parameters / Security (Enable / Disable HTTP, FTP, and TFTP)”: https://www.se.com/ww/en/download/document/35006192K01000</p> <p>For further information, please check the “Premium and Atrium using EcoStruxure™ Control Expert - Ethernet Network Modules, User Manual” and the Modicon Controllers Platform Cyber Security Reference Manual</p>
--	---

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network for the devices that it is intended for.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

Schneider Electric Security Notification

Acknowledgements

Schneider Electric recognizes the following researchers for identifying and helping to coordinate a response to these vulnerabilities:

CVE	Researchers
CVE-2021-22785 CVE-2021-22788	Peter Cheng from ELEX FEIGONG RESEARCH INSTITUTE
CVE-2021-22787	BDU FSTEC Russia

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services: <https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric's products, visit the company's cybersecurity support portal page:

<https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS "NOTIFICATION") ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN "AS-IS" BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION

About Schneider Electric

Schneider's purpose is to empower all to make the most of our energy and resources, bridging progress and sustainability for all. We call this Life Is On.

Schneider Electric Security Notification

Our mission is to be your digital partner for Sustainability and Efficiency.

We drive digital transformation by integrating world-leading process and energy technologies, end-point to cloud connecting products, controls, software and services, across the entire lifecycle, enabling integrated company management, for homes, buildings, data centers, infrastructure and industries.

We are the most local of global companies. We are advocates of open standards and partnership ecosystems that are passionate about our shared Meaningful Purpose, Inclusive and Empowered values.

www.se.com

Revision Control:

<p>Version 1.0 14 September 2021</p>	<p>Original Release</p>
<p>Version 2.0 13 September 2022</p>	<p>A remediation is available for Modicon M340 X80 Ethernet Communication Modules BMXNOR0200H RTU (page 3) and BMXNOC0401 (page 4).</p>
<p>Version 3.0 14 February 2023</p>	<p>A remediation is available for Modicon M340 Ethernet Communication Modules BMXNOE0100 (H) and BMXNOE0110 (H) (page 4).</p>