

Schneider Electric Security Notification

Modicon PLCs (Programmable Logic Controllers) and PACs (Programmable Automation Controllers)

11 April 2023 (12 March 2024)

Overview

Schneider Electric is aware of multiple vulnerabilities in its [Modicon PLCs \(Programmable Logic Controllers\) and PACs \(Programmable Automation Controllers\)](#).

[Modicon PLCs \(Programmable Logic Controllers\) and PACs \(Programmable Automation Controllers\)](#) control and monitor industrial operations in a sustainable, flexible, efficient, and protected way.

Failure to apply the remediations and mitigations provided below may risk a denial of service of the controller, which could result in disrupted operations.

March 2024 Update: A remediation is available for Modicon MC80 ([page 2](#)).

Affected Products and Versions

Product	CVE-2023-25619	CVE-2023-25620
Modicon M340 CPU (part numbers BMXP34*) <i>Versions prior to sv3.51</i>	x	x
Modicon M580 CPU (part numbers BMEP* and BMEH*) <i>Versions prior to v4.10</i>	x	x
Modicon M580 CPU Safety (part numbers BMEP58*S and BMEH58*S) <i>All Versions</i>	x	x
Modicon Momentum Unity M1E Processor (171CBU*) <i>All Versions</i>	x	x
Modicon MC80 (BMKC80) <i>Versions prior to sv2.0</i>	x	x
Legacy Modicon Quantum (140CPU65*) <i>All Versions</i>		x
Legacy Modicon Premium CPUs (TSXP57*) <i>All Versions</i>	x	x

Schneider Electric Security Notification

Vulnerability Details

CVE ID: **CVE-2023-25619**

CVSS v3.1 Base Score 7.5 | High | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H

CWE-754: Improper Check for Unusual or Exceptional Conditions vulnerability exists that could cause denial of service of the controller when communicating over the Modbus TCP protocol.

CVE ID: **CVE-2023-25620**

CVSS v3.1 Base Score 6.5 | Medium | CVSS:3.1/AV:N/AC:L/PR:L/UI:N/S:U/C:N/I:N/A:H

CWE-754: Improper Check for Unusual or Exceptional Conditions vulnerability exists that could cause denial of service of the controller when a malicious project file is loaded onto the controller by an authenticated user.

Note regarding vulnerability details: The severity of vulnerabilities was calculated using the CVSS Base metrics in version 3.1 ([CVSS v3.1](#)) without incorporating the Temporal and Environmental metrics. Schneider Electric recommends that customers score the CVSS Environmental metrics, which are specific to end-user organizations, and consider factors such as the presence of mitigations in that environment. Environmental metrics may refine the relative severity posed by the vulnerabilities described in this document within a customer's environment.

Remediation

Affected Product & Version	Remediation
Modicon M340 CPU (part numbers BMXP34*) <i>Versions prior to sv3.51</i>	Firmware sv3.51 includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/product-range/1468-modicon-m340/#software-and-firmware
Modicon M580 (part numbers BMEP* and BMEH*, excluding M580 CPU Safety) <i>Versions prior to sv4.10</i>	Firmware sv4.10 includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMEx58x0x0_SV04.10/
Modicon MC80 (BMKC80) <i>Versions prior to sv2.0</i>	Firmware sv2.0 includes a fix for these vulnerabilities and is available for download here: https://www.se.com/ww/en/download/document/BMKC80_Firmware_upgrade/

Schneider Electric Security Notification

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric’s [Customer Care Center](#) if you need assistance removing a patch.

If customers choose not to apply the remediation provided above, they should immediately apply the following mitigations to reduce the risk of exploit:

Mitigations

- Setup an application password in the project properties.
- Setup network segmentation and implement a firewall to block all unauthorized access to port 502/TCP.

For Modicon Controllers, when loading a project file through EcoStruxure™ Control Expert, ensure the following:

- Enable the file encryption feature for all new projects.
- Encrypt project files when stored and restrict the access to only trusted users.
- When exchanging files over the network, use secure communication protocols.
- Only open project files received from trusted source, and it is recommended to share project files only when configured with the encryption feature.

In addition, the following specific mitigations apply:

Affected Product & Version	Mitigations
<p>Modicon M340 CPU (part numbers BMXP34*) All Versions</p>	<ul style="list-style-type: none"> • Configure the Access Control List following the recommendations of the user manuals “Modicon M340 for Ethernet Communications Modules and Processors User Manual” in chapter “Messaging Configuration Parameters”: https://www.se.com/ww/en/download/document/31007131K01000/ • Setup a secure communication according to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual,” in chapter “Setup secured communications”: https://www.se.com/ww/en/download/document/EIO0000001999/ • Consider use of external firewall devices such as EAGLE40-07 from Belden to establish VPN connections for M340 & M580 architectures. For more details refer to the chapter “How to protect M580 and M340 architectures with EAGLE40 using VPN”: https://www.se.com/ww/en/download/document/EIO0000001999/

Schneider Electric Security Notification

	<ul style="list-style-type: none"> • Ensure the M340 CPU is running with the memory protection activated by configuring the input bit to a physical input, for more details refer to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual”, “CPU Memory Protection section”: https://www.schneider-electric.com/en/download/document/EIO0000001999/
<p>Modicon M580 CPU (part numbers BMEP* and BMEH*) <i>Versions prior to v4.10</i></p>	<ul style="list-style-type: none"> • Configure the Access Control List following the recommendations of the user manuals: “Modicon M580, Hardware, Reference Manual”: https://www.se.com/ww/en/download/document/EIO0000001578/ • Setup a secure communication according to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual,” in chapter “Setup secured communications”: https://www.se.com/ww/en/download/document/EIO0000001999/ <ul style="list-style-type: none"> • use a BMENOC module and follow the instructions to configure IPSEC feature as described in the guideline “Modicon M580 - BMENOC03.1 Ethernet Communications Schneider Electric Security Notification Module, Installation and Configuration Guide” in the chapter “Configuring IPSEC communications”: https://www.se.com/ww/en/download/document/HRB62665/ <p>OR</p> <ul style="list-style-type: none"> • Use a BMENUA0100 module and follow the instructions to configure IPSEC feature as described in the chapter “Configuring the BMENUA0100 Cybersecurity Settings”: https://www.se.com/ww/en/download/document/PHA83350 <p>OR</p> <ul style="list-style-type: none"> • Consider use of external firewall devices such as EAGLE40-07 from Belden to establish VPN connections for M340 & M580 architectures. For more details refer to the chapter “How to protect M580 and M340 architectures with EAGLE40 using VPN”: https://www.se.com/ww/en/download/document/EIO0000001999/ • Ensure the M580 CPU is running with the memory protection activated by configuring the input bit to a physical input, for more details refer to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual”, “CPU Memory Protection section”: https://www.schneider-electric.com/en/download/document/EIO0000001999/

Schneider Electric Security Notification

	<ul style="list-style-type: none"> NOTE: The CPU memory protection cannot be configured with M580 Hot Standby CPUs. In such cases, use IPsec encrypted communication.
<p>Modicon M580 CPU Safety (BMEP58*S and BMEH58*S) <i>All Versions</i></p>	<p>Schneider Electric is establishing a remediation plan for all future versions of Modicon M580 Safety controllers that will include a fix for these vulnerabilities. We will update this document when the remediation is available. Until then, customers should immediately apply the following mitigations to reduce the risk of exploit:</p> <ul style="list-style-type: none"> Configure the Access Control List following the recommendations of the user manuals: “Modicon M580, Hardware, Reference Manual” https://www.se.com/ww/en/download/document/EIO0000001578/ Setup a secure communication according to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual,” in chapter “Setup secured communications”: https://www.se.com/ww/en/download/document/EIO0000001999/ <ul style="list-style-type: none"> use a BMENOC module and follow the instructions to configure IPSEC feature as described in the guideline “Modicon M580 - BMENOC03.1 Ethernet Communications Schneider Electric Security Notification Module, Installation and Configuration Guide” in the chapter “Configuring IPSEC communications”: https://www.se.com/ww/en/download/document/HRB62665/ <p>OR</p> <ul style="list-style-type: none"> Use a BMENUA0100 module and follow the instructions to configure IPSEC feature as described in the chapter “Configuring the BMENUA0100 Cybersecurity Settings”: https://www.se.com/ww/en/download/document/PHA83350 <p>OR</p> <ul style="list-style-type: none"> Consider use of external firewall devices such as EAGLE40-07 from Belden to establish VPN connections for M340 & M580 architectures. For more details refer to the chapter “How to protect M580 and M340 architectures with EAGLE40 using VPN”: https://www.se.com/ww/en/download/document/EIO0000001999/ Ensure the M580 CPU is running with the memory protection activated by configuring the input bit to a physical input, for more details refer to the following guideline “Modicon Controllers

Schneider Electric Security Notification

	<p>Platform Cyber Security Reference Manual”, “CPU Memory Protection section”: https://www.schneider-electric.com/en/download/document/EIO0000001999/</p> <ul style="list-style-type: none"> NOTE: The CPU memory protection cannot be configured with M580 Hot Standby CPUs. In such cases, use IPsec encrypted communication. <p>To further reduce the attack surface on Modicon M580 CPU Safety:</p> <ul style="list-style-type: none"> Ensure the CPU is running in Safety mode and maintenance input is configured to maintain this Safety mode during operation – refer to the document Modicon M580 - Safety System Planning Guide - in the chapter “Operating Mode Transitions”: https://www.se.com/ww/en/download/document/QGH60283/
<p>Modicon MOMENTUM Unity M1E Processor(171CBU*) <i>All Versions</i></p>	<p>Schneider Electric is establishing a remediation plan for all future versions of Momentum Unity M1E Processors that will include a fix for these vulnerabilities. We will update this document when the remediation is available. Until then, customers should immediately apply the following mitigations to reduce the risk of exploit:</p> <ul style="list-style-type: none"> Configure the Access Control List following the recommendations of the user manuals: <ul style="list-style-type: none"> “Momentum for EcoStruxure™ Control Expert – 171 CBU 78090, 171 CBU 98090, 171 CBU 98091 Processors” manual in the chapter “Modbus Messaging and Access Control”: https://www.se.com/ww/en/download/document/HRB44124/ Setup a secure communication according to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual,” in chapter “Setup secured communications”: https://www.se.com/ww/en/download/document/EIO0000001999/
<p>Modicon MC80 (BMKC80) <i>All Versions</i></p>	<ul style="list-style-type: none"> Configure the Access Control List following the recommendations of the user manuals: <ul style="list-style-type: none"> “Modicon MC80 Programmable Logic Controller (PLC) manual” in the chapter “Access Control List (ACL)”: https://www.se.com/ww/en/download/document/EIO0000002071/ Setup a secure communication according to the following guideline “Modicon Controllers Platform Cyber Security Reference Manual,” in chapter “Setup secured communications”: https://www.se.com/ww/en/download/document/EIO0000001999/

Schneider Electric Security Notification

<p>Modicon Premium CPU (TSXP5*) & Quantum CPU (140CPU65*), All Versions</p>	<p>Schneider Electric’s Modicon Premium & Quantum controllers have reached their end of life and are no longer commercially available. They have been replaced by the Modicon M580 ePAC controller, our most current product offer.</p> <p>Customers should strongly consider migrating to the Modicon M580 ePAC. Please contact your local Schneider Electric technical support for more information.</p> <p>To mitigate the risks users should immediately:</p> <ul style="list-style-type: none"> • Configure the Access Control List following the recommendations of the user manual “Premium and Atrium using EcoStruxure™ Control Expert – Ethernet Network Modules, User Manual” in chapters “Connection configuration parameters / TCP/IP Services Configuration Parameters / Connection Configuration Parameters”: https://www.se.com/ww/en/download/document/35006192K01000/
--	---

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network intended for that device.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

Schneider Electric Security Notification

Acknowledgements

Schneider Electric recognizes the following researcher for identifying and helping to coordinate a response to these vulnerabilities:

CVE	Researcher
CVE-2023-25619 CVE-2023-25620	Sun Yue, Chinese Academy of Sciences

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services: <https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric's products, visit the company's cybersecurity support portal page:

<https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS "NOTIFICATION") ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN "AS-IS" BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION

About Schneider Electric

Schneider's purpose is to empower all to make the most of our energy and resources, bridging progress and sustainability for all. We call this Life Is On.

Our mission is to be your digital partner for Sustainability and Efficiency.

Schneider Electric Security Notification

We drive digital transformation by integrating world-leading process and energy technologies, end-point to cloud connecting products, controls, software and services, across the entire lifecycle, enabling integrated company management, for homes, buildings, data centers, infrastructure and industries.

We are the most local of global companies. We are advocates of open standards and partnership ecosystems that are passionate about our shared Meaningful Purpose, Inclusive and Empowered values.

www.se.com

Revision Control:

<p>Version 1.0.0 11 April 2023</p>	<p>Original Release</p>
<p>Version 2.0.0 12 March 2024</p>	<p>A remediation is available for Modicon MC80 (page 2).</p>