

Schneider Electric Security Notification

IGSS (Interactive Graphical SCADA System)

12 September 2023

Overview

Schneider Electric is aware of a vulnerability in its Update Service for the IGSS (Interactive Graphical SCADA System) product.

The [IGSS](#) product is a state-of-the-art SCADA system used for monitoring and controlling industrial processes. The IGSS Update Service handles IGSS Software to be updated.

Failure to apply the remediation provided below may risk remote code execution, which could result in a variety of issues including loss of control of the SCADA System with IGSS running in production mode.

Affected Products and Versions

Product	Version
IGSS Update Service (IGSSupdateservice.exe)	v16.0.0.23211 and prior

Vulnerability Details

CVE ID: **CVE-2023-4516**

CVSS v3.1 Base Score 7.8 | High | CVSS:3.1/AV:L/AC:L/PR:L/UI:N/S:U/C:H/I:H/A:H

A *CWE-306: Missing Authentication for Critical Function* vulnerability exists in the IGSS Update Service that could allow a local attacker to change update source, potentially leading to remote code execution when the attacker force an update containing malicious content.

Note regarding vulnerability details: The severity of vulnerabilities was calculated using the CVSS Base metrics in version 3.1 ([CVSS v3.1](#)) without incorporating the Temporal and Environmental metrics. Schneider Electric recommends that customers score the CVSS Environmental metrics, which are specific to end-user organizations, and consider factors such as the presence of mitigations in that environment. Environmental metrics may refine the relative severity posed by the vulnerabilities described in this document within a customer's environment.

Schneider Electric Security Notification

Remediation

Affected Product & Version	Remediation
IGSS Update Service <i>v16.0.0.23211 and prior</i>	Version 16.0.0.23212 of the IGSS Update Service includes a fix for this vulnerability and is available for download through IGSS Master > Update IGSS Software or here: https://igss.schneider-electric.com/igss/igssupdates/v160/IGSSUPDATE.ZIP

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric’s [Customer Care Center](#) if you need assistance removing a patch.

If customers choose not to apply the remediation provided above, they should immediately apply the following mitigations to reduce the risk of exploit:

- Disable the IGSS Update Service as an Administrator, and only enable it while installing new updates.
- Read the [Security Guideline](#) for IGSS on securing an IGSS SCADA-installation.
- Follow the general security recommendation below and verify that devices are isolated on a private network and that firewalls are configured with strict boundaries for devices that require remote access.

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network intended for that device.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.

Schneider Electric Security Notification

- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

Acknowledgements

Schneider Electric recognizes the following researcher for identifying and helping to coordinate a response to this vulnerability:

CVE	Researcher
CVE-2023-4516	Sina Kheirkhah (@SinSinology) of Summoning Team (@SummoningTeam) working with Trend Micro Zero Day Initiative

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services: <https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric's products, visit the company's cybersecurity support portal page: <https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS "NOTIFICATION") ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN "AS-IS" BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY

Schneider Electric Security Notification

DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION.

About Schneider Electric

Schneider’s purpose is to empower all to make the most of our energy and resources, bridging progress and sustainability for all. We call this Life Is On.

Our mission is to be your digital partner for Sustainability and Efficiency.

We drive digital transformation by integrating world-leading process and energy technologies, end-point to cloud connecting products, controls, software and services, across the entire lifecycle, enabling integrated company management, for homes, buildings, data centers, infrastructure and industries.

We are the most local of global companies. We are advocates of open standards and partnership ecosystems that are passionate about our shared Meaningful Purpose, Inclusive and Empowered values.

www.se.com

Revision Control:

<p>Version 1.0 12 September 2023</p>	<p>Original Release</p>
---	-------------------------