

Schneider Electric Security Notification

EcoStruxure™ Power Build Rapsody

14 January 2025 (13 May 2025)

Overview

Schneider Electric is aware of a vulnerability in its EcoStruxure™ Power Build Rapsody software.

The [EcoStruxure™ Power Build Rapsody](#) is used to enter or import the single line diagram, to get the extensive bill of material of your switchboard, including all devices, connection items, and mounting components

Failure to apply the remediations and mitigations provided below may risk memory corruption, heap-based buffer overflow, stack-based buffer overflow, which could result in local attackers being able to exploit these issues to potentially execute arbitrary code.

May 2025 Update: A remediation is available for this vulnerability in V2.8.4 INT and corrected the Affected Products and Versions table with EcoStruxure™ Power Build–Rapsody INT version.

Affected Products and Versions

Product	Version
EcoStruxure™ Power Build Rapsody	Version v2.5.2 NL and prior Version v2.7.1 FR and prior Version v2.7.5 ES and prior Version v2.6.4 INT and prior

Vulnerability Details

CVE ID: **CVE-2024-11139**

CVSS v3.1 Base Score 5.3 | Medium | CVSS:3.1/AV:L/AC:L/PR:N/UI:R/S:U/C:L/I:L/A:L

CVSS v4.0 Base Score 4.6 | Medium | CVSS:4.0/AV:L/AC:L/AT:N/PR:N/UI:A/VC:L/VI:L/VA:L/SC:N/SI:N/SA:N

CWE-119: Improper Restriction of Operations within the Bounds of a Memory Buffer vulnerability exists that could allow local attackers to exploit these issues to potentially execute arbitrary code when opening a malicious project file.

The severity of vulnerabilities was calculated using the CVSS Base metrics for 4.0 ([CVSS v4.0](#)). CVSS v3.1 will be still evaluated until the adoption of CVSS v4.0 by the industry. The severity was calculated without incorporating the Temporal and Environmental metrics. Schneider Electric recommends that customers score the CVSS Environmental metrics, which are specific to end-user organizations, and consider factors such as the presence of mitigations in that environment. Environmental metrics may refine the relative severity posed by the vulnerabilities described in this document within a customer's environment.

Schneider Electric Security Notification

Remediation

Affected Product & Version	Remediation
EcoStruxure™ Power Build–Rapsody <i>v2.7.5 ES and prior</i>	Version v2.7.52 ES of EcoStruxure™ Power Build–Rapsody includes a fix for this vulnerability and are available for download here: https://www.se.com/es/es/product-range/2309-ecostruxure-power-build-rapsody/#software-and-firmware Please reboot the system after installing the new version.
EcoStruxure™ Power Build–Rapsody <i>v2.7.1 FR and prior</i>	Version v2.7.12 FR of EcoStruxure™ Power Build–Rapsody includes a fix for this vulnerability and are available for download here: https://www.se.com/fr/fr/product-range/2309-ecostruxure-power-build-rapsody/#software-and-firmware Please reboot the system after installing the new version.
EcoStruxure™ Power Build–Rapsody <i>v2.5.2 NL and prior</i>	Version v2.7.2 NL of EcoStruxure™ Power Build–Rapsody includes a fix for this vulnerability and are available for download here: https://www.se.com/nl/nl/product-range/2309-ecostruxure-power-build-rapsody/#software-and-firmware Please reboot the system after installing the new version.
EcoStruxure™ Power Build–Rapsody <i>Version v2.6.4 INT and prior</i>	Version v2.8.4 INT of EcoStruxure™ Power Build–Rapsody includes a fix for this vulnerability and is available for download here: https://www.se.com/ww/en/product-range/2309-ecostruxure-power-build-rapsody/#overview Please reboot the system after installing the new version.

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric's [Customer Care Center](#) if you need assistance removing a patch.

Schneider Electric Security Notification

Mitigations

Affected Product & Version	Mitigations
EcoStruxure™ Power Build–Rapsody <i>Version v2.5.2 NL and prior</i> <i>Version v2.7.1 FR and prior</i> <i>Version v2.7.5 ES and prior</i> <i>Version v2.6.4 INT and prior</i>	<p>If customers choose not to apply the remediation provided above, they should immediately apply the following mitigations to reduce the risk of exploit:</p> <ul style="list-style-type: none">• Only open projects from trusted sources.• Ensure use of Malware scans before opening any externally created Project• Encrypt project file when stored and restrict the access to only trusted users.• When exchanging files over the network, use secure communication protocols.• Compute a hash of the project files and regularly check the consistency of this hash to verify the integrity before usage. <p>To ensure you are informed of all updates, including details on affected products and remediation plans, subscribe to Schneider Electric's security notification service here: https://www.se.com/en/work/support/cybersecurity/security-notifications.jsp</p>

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network intended for that device.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

Schneider Electric Security Notification

Acknowledgements

Schneider Electric recognizes the following researcher for identifying and helping to coordinate a response to this vulnerability:

CVE	Researcher
CVE-2024-11139	Michael Heinzl

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services:

<https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric's products, visit the company's cybersecurity support portal page: <https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS "NOTIFICATION") ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN "AS-IS" BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION.

About Schneider Electric

Schneider's purpose is to **create Impact** by empowering all to **make the most of our energy and resources**, bridging progress and sustainability for all. We call this Life Is On.

Our mission is to be the trusted partner in **Sustainability and Efficiency**.

We are a **global industrial technology leader** bringing world-leading expertise in electrification, automation and digitization to smart **industries**, resilient **infrastructure**, future-proof **data centers**, intelligent **buildings**, and intuitive **homes**. Anchored by our deep

Schneider Electric Security Notification

domain expertise, we provide integrated end-to-end lifecycle AI enabled Industrial IoT solutions with connected products, automation, software and services, delivering digital twins to enable profitable growth **for our customers**.

We are a **people company** with an ecosystem of 150,000 colleagues and more than a million partners operating in over 100 countries to ensure proximity to our customers and stakeholders. We embrace **diversity and inclusion** in everything we do, guided by our meaningful purpose of a **sustainable future for all**.

www.se.com

Revision Control:

Version 1.0.0 14 January 2025	Original Release
Version 2.0.0 13 May 2025	A remediation is available for this vulnerability in V2.8.4 INT and corrected the Affected Products and Versions table with EcoStruxure™ Power Build–Rhapsody INT version.