

Schneider Electric Security Notification

Improper Check for Unusual or Exceptional Conditions on Multiple Products

10 February 2026

Overview

Schneider Electric is aware of a vulnerability in its SCADAPack™ x70 RTU products.

The [SCADAPack™ 47xi](#), [SCADAPack™ 47x](#) and [SCADAPack™ 57x](#) product are Remote Terminal Units that provide communication capabilities for remote monitoring and control.

Failure to apply the remediations provided below may risk unauthorized access to your RTU, which could result in the possibility of denial of service and loss of confidentiality, integrity of the controller.

Affected Products and Versions

Product	Version
SCADAPack™ 47x SCADAPack™ 47xi	Versions prior to R3.4.2 (Firmware version prior to 9.12.2)
SCADAPack™ 57x	All Versions
RemoteConnect	Versions prior to R3.4.2

Vulnerability Details

CVE ID: **CVE-2026-0667**

CVSS v3.1 Base Score 9.8 | Critical | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:H/I:H/A:H

CVSS v4.0 Base Score 9.3 | Critical | CVSS:4.0/AV:N/AC:L/AT:N/PR:N/UI:N/VC:H/VI:H/VA:H/SC:N/SI:N/SA:N

CWE-754: Improper Check for Unusual or Exceptional Conditions vulnerability that could cause arbitrary code execution, denial of service and loss of confidentiality & integrity when communicating over the Modbus TCP protocol.

The severity of vulnerabilities was calculated using the CVSS Base metrics for 4.0 ([CVSS v4.0](#)). CVSS v3.1 will be still evaluated until the adoption of CVSS v4.0 by the industry. The severity was calculated without incorporating the Temporal and Environmental metrics. Schneider Electric recommends that customers score the CVSS Environmental metrics, which are specific to end-user organizations, and consider factors such as the presence of mitigations in that environment. Environmental metrics may refine the relative severity posed by the vulnerabilities described in this document within a customer's environment.

Remediation

Schneider Electric Security Notification

Affected Product & Version	Remediation
SCADAPack™ 47x SCADAPack™ 47xi <i>Versions prior to R3.4.2</i> <i>(Firmware version prior to 9.12.2)</i>	Version R3.4.2 (Firmware version 9.12.2) of SCADAPack™ 47x and SCADAPack™ 47xi includes a fix for this vulnerability and is available for download here: https://www.se.com/ww/en/download/document/RemoteConnect/
RemoteConnect <i>Versions prior to R3.4.2</i>	Version R3.4.2 of RemoteConnect includes a fix for this vulnerability and is available for download here: https://www.se.com/ww/en/download/document/RemoteConnect/

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric's Technical Support at supportRO@se.com if you need assistance.

If customers choose not to apply the remediation provided above, they should immediately apply the following mitigations to reduce the risk of exploit:

Mitigations

Affected Product & Version	Mitigations
SCADAPack™ 47x SCADAPack™ 47xi RemoteConnect <i>Versions prior to R3.4.2</i> <i>(Firmware version prior to 9.12.2)</i>	Follow the information according to SCADAPack™ Security Guidelines in section 8.3 Secured Communication. Also, apply the following standard practices to reduce the risk of exploit: <ul style="list-style-type: none">• Setup network segmentation and implement the RTU firewall service to block all unauthorized access to services• Disable the logic debug service.
SCADAPack™ 57x <i>All Versions</i>	Follow the information according to SCADAPack™ Security Guidelines in section 8.3 Secured Communication. Also, apply the following standard practices to reduce the risk of exploit: <ul style="list-style-type: none">• Setup network segmentation and implement the RTU firewall service to block all unauthorized access to services.• Disable the logic debug service.

To ensure you are informed of all updates, including details on affected products and remediation plans, subscribe to Schneider Electric's security notification service here:

Schneider Electric Security Notification

<https://www.se.com/en/work/support/cybersecurity/security-notifications.jsp>

General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network intended for that device.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services:

<https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric’s products, visit the company’s cybersecurity support portal page: <https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS “NOTIFICATION”) ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN “AS-IS” BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN

Schneider Electric Security Notification

RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION.

About Schneider Electric

Schneider's purpose is to **create Impact** by empowering all **to make the most of our energy and resources**, bridging progress and sustainability for all. We call this Life Is On.

Our mission is to be the trusted partner in **Sustainability and Efficiency**.

We are a **global industrial technology leader** bringing world-leading expertise in electrification, automation and digitization to smart **industries**, resilient **infrastructure**, future-proof **data centers**, intelligent **buildings**, and intuitive **homes**. Anchored by our deep domain expertise, we provide integrated end-to-end lifecycle AI enabled Industrial IoT solutions with connected products, automation, software and services, delivering digital twins to enable profitable growth **for our customers**.

We are a **people company** with an ecosystem of 150,000 colleagues and more than a million partners operating in over 100 countries to ensure proximity to our customers and stakeholders. We embrace **diversity and inclusion** in everything we do, guided by our meaningful purpose of a **sustainable future for all**.

www.se.com

Revision Control:

Version 1.0.0 10 February 2026	Original Release
--	------------------