

# Schneider Electric Security Notification

## Multiple Vulnerabilities on EasyLogic T150 and Saitel DP RTU

09 June 2026

### Overview

Schneider Electric is aware of a vulnerability in its EasyLogic T150 (formerly known as Saitel DR) and Saitel DP Remote Terminal Unit & Controller products.

The [EasyLogic T150 \(formerly known as Saitel DR RTU\)](#) is a field device, offering a solid and powerful modular platform for data acquisition, communication, automation and IED integration for distribution and transmission networks, generation sector and railway.

The [Saitel DP RTU](#) is a modular platform for medium voltage and high voltage public distribution and transmission substation control.

Failure to apply the mitigations provided below may risk credential harvesting and unauthorized access attacks, which could result in exposure of sensitive information and compromise of device integrity and operations when an attacker has subsequent physical access to the device.

### Affected Products and Versions

Product	CVE-2026-9650	CVE-2026-9651
EasyLogic T150 (formerly Saitel DR) Remote Terminal Unit & Controller	Versions 11.06.30 and prior	Version 11.06.31 and prior
Saitel DP Remote Terminal Unit & Controller	Versions 11.06.35 and prior	Version 11.06.37 and prior

### Vulnerability Details

CVE ID: CVE-2026-9650

CVSS v3.1 Base Score 7.5 | High | CVSS:3.1/AV:N/AC:L/PR:N/UI:N/S:U/C:H/I:N/A:N

CVSS v4.0 Base Score 8.7 | High | CVSS:4.0/AV:N/AC:L/AT:N/PR:N/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N

*CWE-522 Insufficiently Protected Credentials* vulnerability that could cause unauthorized access and exposure of sensitive information when unauthenticated attacker accesses credentials stored within firmware or system files. With this credential an attacker could subsequently compromise the device if they have physical access to the device.

CVE ID: CVE-2026-9651

CVSS v3.1 Base Score 4.4 | Medium | CVSS:3.1/AV:L/AC:L/PR:H/UI:N/S:U/C:H/I:N/A:N

CVSS v4.0 Base Score 6.7 | Medium | CVSS:4.0/AV:L/AC:L/AT:N/PR:H/UI:N/VC:H/VI:N/VA:N/SC:N/SI:N/SA:N

09-Jun-26

Document Reference Number – SEVD-2026-160-02

Page 1 of 4

Public / TLP: Clear

## Schneider Electric Security Notification

*CWE-732 Incorrect Permission Assignment for Critical Resource* vulnerability that could cause unauthorized disclosure of password hashes and potential account compromise when an attacker with privileged local access reads improperly protected system files.

*The severity of vulnerabilities was calculated using the CVSS Base metrics for 4.0 ([CVSS v4.0](#)). CVSS v3.1 will be still evaluated until the adoption of CVSS v4.0 by the industry. The severity was calculated without incorporating the Temporal and Environmental metrics. Schneider Electric recommends that customers score the CVSS Environmental metrics, which are specific to end-user organizations, and consider factors such as the presence of mitigations in that environment. Environmental metrics may refine the relative severity posed by the vulnerabilities described in this document within a customer's environment.*

### Remediation

Affected Product & Version	Remediation
<b>EasyLogic T150 (formerly Saitel DR) Remote Terminal Unit &amp; Controller</b>  <i>Versions 11.06.31 and prior</i>	Version 11.06.32 of EasyLogic T150 (formerly Saitel DR) Remote Terminal Unit & Controller includes a fix for these vulnerabilities and is available: <ul style="list-style-type: none"> <li>• Contact Schneider Electric's Customer Care Center to download this firmware.</li> <li>• Reboot needed: Yes.</li> </ul>
<b>SAITEL DP Remote Terminal Unit &amp; Controller</b>  <i>Versions 11.06.37 and prior</i>	Version 11.06.38 of SAITEL DP Remote Terminal Unit & Controller includes a fix for these vulnerabilities and is available: <ul style="list-style-type: none"> <li>• Contact Schneider Electric's Customer Care Center to download this firmware.</li> <li>• Reboot needed: Yes.</li> </ul>

Customers should use appropriate patching methodologies when applying these patches to their systems. We strongly recommend the use of back-ups and evaluating the impact of these patches in a Test and Development environment or on an offline infrastructure. Contact Schneider Electric's [Customer Care Center](#) if you need assistance removing a patch.

To ensure you are informed of all updates, including details on affected products and remediation plans, subscribe to Schneider Electric's security notification service here:

<https://www.se.com/en/work/support/cybersecurity/security-notifications.jsp>

### General Security Recommendations

We strongly recommend the following industry cybersecurity best practices.

## Schneider Electric Security Notification

- Locate control and safety system networks and remote devices behind firewalls and isolate them from the business network.
- Install physical controls so no unauthorized personnel can access your industrial control and safety systems, components, peripheral equipment, and networks.
- Place all controllers in locked cabinets and never leave them in the “Program” mode.
- Never connect programming software to any network other than the network intended for that device.
- Scan all methods of mobile data exchange with the isolated network such as CDs, USB drives, etc. before use in the terminals or any node connected to these networks.
- Never allow mobile devices that have connected to any other network besides the intended network to connect to the safety or control networks without proper sanitation.
- Minimize network exposure for all control system devices and systems and ensure that they are not accessible from the Internet.
- When remote access is required, use secure methods, such as Virtual Private Networks (VPNs). Recognize that VPNs may have vulnerabilities and should be updated to the most current version available. Also, understand that VPNs are only as secure as the connected devices.

For more information refer to the Schneider Electric [Recommended Cybersecurity Best Practices](#) document.

### Acknowledgements

Schneider Electric recognizes the following researcher for identifying and helping to coordinate a response to this vulnerability:

CVE	Researcher
CVE-2026-9650	Dick Brooks, Business Cyber Guardian
CVE-2026-9651	Internal Schneider Electric Researcher

### For More Information

This document provides an overview of the identified vulnerability or vulnerabilities and actions required to mitigate. For more details and assistance on how to protect your installation, contact your local Schneider Electric representative or Schneider Electric Industrial Cybersecurity Services:

<https://www.se.com/ww/en/work/solutions/cybersecurity/>. These organizations will be fully aware of this situation and can support you through the process.

For further information related to cybersecurity in Schneider Electric’s products, visit the company’s cybersecurity support portal page: <https://www.se.com/ww/en/work/support/cybersecurity/overview.jsp>

LEGAL DISCLAIMER

## Schneider Electric Security Notification

THIS NOTIFICATION DOCUMENT, THE INFORMATION CONTAINED HEREIN, AND ANY MATERIALS LINKED FROM IT (COLLECTIVELY, THIS “NOTIFICATION”) ARE INTENDED TO HELP PROVIDE AN OVERVIEW OF THE IDENTIFIED SITUATION AND SUGGESTED MITIGATION ACTIONS, REMEDIATION, FIX, AND/OR GENERAL SECURITY RECOMMENDATIONS AND IS PROVIDED ON AN “AS-IS” BASIS WITHOUT WARRANTY OR GUARANTEE OF ANY KIND. SCHNEIDER ELECTRIC DISCLAIMS ALL WARRANTIES RELATING TO THIS NOTIFICATION, EITHER EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. SCHNEIDER ELECTRIC MAKES NO WARRANTY THAT THE NOTIFICATION WILL RESOLVE THE IDENTIFIED SITUATION. IN NO EVENT SHALL SCHNEIDER ELECTRIC BE LIABLE FOR ANY DAMAGES OR LOSSES WHATSOEVER IN CONNECTION WITH THIS NOTIFICATION, INCLUDING DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, LOSS OF BUSINESS PROFITS OR SPECIAL DAMAGES, EVEN IF SCHNEIDER ELECTRIC HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. YOUR USE OF THIS NOTIFICATION IS AT YOUR OWN RISK, AND YOU ARE SOLELY LIABLE FOR ANY DAMAGES TO YOUR SYSTEMS OR ASSETS OR OTHER LOSSES THAT MAY RESULT FROM YOUR USE OF THIS NOTIFICATION. SCHNEIDER ELECTRIC RESERVES THE RIGHT TO UPDATE OR CHANGE THIS NOTIFICATION AT ANY TIME AND IN ITS SOLE DISCRETION.

### About Schneider Electric

Schneider’s purpose is to **create Impact** by empowering all **to make the most of our energy and resources**, bridging progress and sustainability for all. We call this Life Is On.

Our mission is to be the trusted partner in **Sustainability and Efficiency**.

We are a **global industrial technology leader** bringing world-leading expertise in electrification, automation and digitization to smart **industries**, resilient **infrastructure**, future-proof **data centers**, intelligent **buildings**, and intuitive **homes**. Anchored by our deep domain expertise, we provide integrated end-to-end lifecycle AI enabled Industrial IoT solutions with connected products, automation, software and services, delivering digital twins to enable profitable growth **for our customers**.

We are a **people company** with an ecosystem of 150,000 colleagues and more than a million partners operating in over 100 countries to ensure proximity to our customers and stakeholders. We embrace **diversity and inclusion** in everything we do, guided by our meaningful purpose of a **sustainable future for all**.

[www.se.com](http://www.se.com)

Revision Control:

<b>Version 1.0.0</b> 09 June 2026	Original Release
--------------------------------------	------------------