



We help ideas meet the real world

Attestation of Conformity

No. 2013-505

Screened Channel, Class E_A

Company

Schneider Electric Industries SAS
35 rue Joseph Monier
CS 30323
92506 Rueil Malmaison Cedex
France

Channel Identification (4 connector model)

Terminal cord: VDIP185X46030: Actassi CL-MNC6A Cord, 3m long SFTP Cat6_A LSZH

CP Cabling: VDICP4X0xx0y: Actassi CL-MNC6A CP Cable, SFTP Cat6_A AWG26 LSZH
(xx denotes the length between 05 and 15 m, y denotes the footprint version)

Horizontal cable: VDIC68Xxxx: Actassi CL-MXC6A Cable, F/FTP Cat6_A, LSZH
(xxx denotes the version and the packaging)

Patch cord: VDIP185X46020: Actass iCL-MNC6A Cord, 2m long SFTP Cat6_A LSZH

Equipment cord: VDICP4X0xx0y: Actassi CL-MNC6A CP Cable, 4m long SFTP Cat6_A AWG26 LSZH

RJ45 socket: VDIB177xXByy: Screened Cat6_A Connector
(x denotes the footprint version, yy denotes the packaging size)

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report


DELTA- T206634-01, DANAK-19/13638

EC Cabling product ID

5608

These product samples have undergone a one-time test performed by DELTA EC Cabling Group and comply with the requirements of the above specified standards for screened Channels, Class E_A.

Hørsholm, 12 December 2013


Lars Lindskov Pedersen
Test Manager


Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable