



We help ideas meet the real world

Attestation of Conformity

No. 2013-509

Screened Permanent Link, Class E_A

Company

Schneider Electric Industries SAS
35 rue Joseph Monier
CS 30323
92506 Rueil Malmaison Cedex
France

Permanent Link Identification (3 connector model)

Horizontal cable: Actassi CL-MNC6A VDIC64Xxxx F/FTP LSZH
(xxx denotes the version and the packaging)

CP Link: Actassi CL-MNC6A VDICP4X0xx0y S/FTP
(xx denotes the length, y denotes the footprint version)

RJ45 sockets: VDIB177xXByy
(x denotes the footprint version, yy denotes the packaging size)

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-T206634-05, DANAK-19/13642

EC Cabling product ID

5335

These product samples have undergone a one time test performed by DELTA EC Cabling Group and comply with the requirements of the above specified standards for Permanent Links, Class E_A.

Hørsholm, 12 December 2013

Test Manager

Claude Viellet
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable