

Originator's Report Number: 94002297.01

December 20, 1994

Test Report  
for  
**American Power Conversion**  
on the  
**SmartShot Call-UPS II**  
**Remote Management Device**



AP9608

Tests Performed by

Dash, Straus & Goodhue, Inc.  
593 Massachusetts Avenue  
Boxborough, MA 01719

Tests Authorized by

American Power Conversion  
9 Executive Park Drive  
Billerica, MA 01862

Test Initiated								December 5, 1994
Test Completed								December 5, 1994
Test Engineer								12-23-94 Michael M. Houston
Supervisor								12/23/94 Robert Martin

MMH/Dal



# Inchcape Testing Services

## Dash, Straus & Goodhue

593 Massachusetts Avenue  
Boxborough, MA 01719  
Telephone (508) 263-2662  
Fax (508) 263-7086

December 23, 1994

*AP9608*

Mr. Joe Pomata  
American Power Conversion  
9 Executive Park Drive  
Billerica, MA 01862

Dear Mr. Pomata:

Enclosed you will find our test report covering testing on the SmartShot Call-UPS II Remote Management Device. Testing was performed on December 5, 1994.

If you have any questions on the content of the report or the performance of the test, please feel free to contact me at (508) 263-2662.

Sincerely,

Robert F. Martin, N.C.E., P.E.  
Chief Engineer

RFM/Dal  
Enclosure

All services undertaken are subject to the following general policy:  
Reports are submitted for exclusive use of the client to whom they are addressed. Their significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations or surveys made. No quotations from reports or use of Dash, Straus & Goodhue's name is permitted except as expressly authorized by Dash, Straus & Goodhue in writing.

# Table of Contents

1.0	<u>Introduction</u> . . . . .	1
1.1	Scope . . . . .	1
1.2	Purpose . . . . .	1
1.3	Summary . . . . .	1
1.4	Testing Requirements . . . . .	1
2.0	<u>Test Environment</u> . . . . .	3
2.1	Test Sample Description . . . . .	3
2.2	Test Facility . . . . .	3
2.3	Test Equipment . . . . .	3
3.0	<u>Test Results</u> . . . . .	5
3.1	IEC 801-2, Electrostatic Discharge Susceptibility . . . . .	5
	3.1.1 Test Description . . . . .	5
	3.1.2 Test Configuration . . . . .	5
	3.1.3 Test Procedure . . . . .	5
	3.1.4 Test Results . . . . .	5
3.2	IEC 801-3, Radiated Susceptibility-Electric Field . . . . .	7
	3.2.1 Test Description . . . . .	7
	3.2.2 Test Configuration . . . . .	7
	3.2.3 Test Procedures . . . . .	7
	3.2.4 Test Results . . . . .	7
3.3	IEC 801-4, Conducted Transients Susceptibility . . . . .	9
	3.3.1 Test Description . . . . .	9
	3.3.2 Testing Configuration . . . . .	9
	3.3.3 Test Procedure . . . . .	9
	3.3.4 Test Results . . . . .	9
4.0	<u>Conclusions</u> . . . . .	12
4.1	IEC 801-2, ESD Susceptibility . . . . .	12
4.2	IEC 801-3, Radiated Susceptibility . . . . .	12
4.3	IEC 801-4, Conducted Susceptibility . . . . .	12
4.4	EN50082-1 Generic Immunity - European Requirements . . . . .	12
	Configuration Photographs . . . . .	13

## List of Figures

Figure 3.1-1 ESD Test Configuration . . . . .	6
Figure 3.2-1 Biconical Antenna Testing Configuration . . . . .	8
Figure 3.3-1 Conducted Susceptibility Test Configuration . . . . .	10
Figure 3.3-2 Burst Transient Waveform . . . . .	11

## List of Tables

Table 1.4-1 Test Parameters . . . . .	2
Table 2.3-1 Test Equipment . . . . .	4

## 1.0 Introduction

### 1.1 Scope

This report covers testing performed on December 5, 1994 on the SmartShot Call-UPS II Remote Management Device manufactured by American Power Conversion.

### 1.2 Purpose

Testing was performed to evaluate the SmartShot Call-UPS II Remote Management Device for susceptibility to ESD, line-conducted burst interference and radiated RFI in accordance with EN50082-1.

### 1.3 Summary

The SmartShot Call-UPS II was found to be compliant to radiated RFI, ESD and line-conducted burst interference in accordance with EN50082-1 without modification.

### 1.4 Testing Requirements

Testing was performed using procedures and criteria contained in IEC 801-2, 801-3, 801-4 and EN50082-1. Table 1.4-1 contains specifics pertaining to testing parameters.

Table 1.4-1 Test Parameters/Compliance Criteria

IEC 801-2, ESD Susceptibility

+8 kV air discharge

Category B Compliance per EN50082-1:1992

IEC 801-3, Radiated Electromagnetic Field Susceptibility

3 V/m, 27 MHz to 500 MHz

Category A Compliance per EN50082-1:1992

IEC 801-4, Conducted Susceptibility to Line Transients

$\pm 0.5$  kV on signal lines,  $\pm 1.0$  kV on power lines

Category B Compliance per EN50082-1:1992

## 2.0 Test Environment

### 2.1 Test Sample Description

The Equipment Under Test (EUT) consisted of a SmartShot Call-UPS II Remote Management Device, manufactured by American Power Conversion. It was received on December 5, 1994 from American Power Conversion in good condition.

The SmartShot Call-UPS II Remote Management Device was installed in a SmartUPS 1400 (S/N: 594114459803) which was supplying power to a Zeos 486 PC with keyboard and an NEC 3FG monitor communicating with the SmartUPS via an RS-232 link. Software ran during testing displayed UPS status and parameters. Failure was defined as a change in parameters outside of specified normal levels, or a loss in output power.

### 2.2 Test Facility

The test facility, Dash, Straus & Goodhue, Inc., is located at 593 Massachusetts Avenue, Boxborough, Massachusetts. The test site is located on the ground floor and consists of a shielded room (16' x 20' x 10') with a test bench to hold the test sample. Ambient temperature is maintained between 65° and 75°F, with an approximate relative humidity of 45%.

### 2.3 Test Equipment

Table 2.3-1 contains a list of the test equipment used during the testing.



Table 2.3-1 Test Equipment

<b>801-2</b>		
CDI ESD1000 Charge Reservoir ESD Simulator		

<b>801-3</b>		
<b>Model No.</b>	<b>Serial No.</b>	<b>Description</b>
ENI 550L-1711	845	Amplifier
ENI 6100L	113	Amplifier
6071A	3215002	Signal Generator
B100	201	Biconical Antenna
B200	202	Biconical Antenna
B300	203	Biconical Antenna
FM2000	14937	Isotropic Field Monitor
FP2000	14904	Isotropic Field Probe
888	12161	Levelling Preamplifier

<b>801-4</b>		
<b>Model No.</b>	<b>Serial No.</b>	<b>Description</b>
Schaffner NSG-200E	3184	Mainframe
Schaffner NSG-225A	1204	Burst Interference Simulator Plug-In




Figure 3.1-1 ESD Test Configuration

## 3.2 IEC 801-3, Radiated Susceptibility-Electric Field

### 3.2.1 Test Description

IEC Publication 801-3:1984, Electromagnetic Compatibility for Industrial Process Measurement and Control Equipment, Part 3: Radiated Electromagnetic Field Requirements, was the guiding document for this test. This test evaluates the test sample's response to radiated electric fields and was performed from 27 to 500 MHz at a level of 3 V/m. The test level was raised to 10 V/m for evaluation purposes.

### 3.2.2 Test Configuration

Figure 3.2-1 shows the testing configurations.

### 3.2.3 Test Procedures

The test sample is set into operation and was monitored for variations in performance. The test signal is set for frequency and field strength. While maintaining the necessary field strength, the frequency is changed until the range appropriate for the current test configuration has been covered. If an error is detected, the field strength is reduced until the error corrects, then increased until the error begins to occur. This threshold level, the frequency and the error created are noted before continuing. The procedure is then repeated in the opposite antenna polarization.

### 3.2.4 Test Results

The test sample was found to be immune to RFI at 10/m from 27 to 500 MHz, in both antenna polarizations, with no modifications.




Figure 3.2-1 Biconical Antenna Testing Configuration

### 3.3 IEC 801-4, Conducted Transients Susceptibility

#### 3.3.1 Test Description

IEC Publication 801-4:1988, Electromagnetic Compatibility for Industrial Process Measurement and Control Equipment, Part 4: Conducted Burst Interference was the guiding document for this test. This test evaluates the test sample's response to burst interference transients conducted on the supply. A test signal of  $\pm 1$  kV is to be applied to both sides of the line and ground and a test signal of  $\pm 0.5$  kV was to be applied to all signal and I/O lines. Target levels of  $\pm 4$  kV for AC lines and  $\pm 2$  kV for I/O cables was set for this test.

#### 3.3.2 Testing Configuration

Figure 3.3-1 shows the testing configuration used. Figure 3.3-2 shows the transient waveform.

#### 3.3.3 Test Procedure

The test sample was connected to the test equipment, as shown in Figure 3.3-1, and monitored for performance. The test level was set and the test signal was applied for the required time to one side of the line (L1). When an error occurs, the test level is reduced until the error recovers and then increased until the threshold level is reached. This threshold and the error conditions were noted. This procedure was repeated while injecting into line 2 (L2), ground (G), then combination of lines and ground (L1 & L2, L1 & L2 & G). The output AC port was also subjected to burst testing in the same manner.

Using a capacitive coupling plate as called out in IEC 801-4, the procedure was then repeated on signal and I/O lines.

#### 3.3.4 Test Results

The EUT did not exhibit errors when testing AC ports up through the  $\pm 1$  kV level. At the next level, 2 kV, UPS reboots occurred. I/O cable testing at  $\pm 0.5$  kV also did not cause errors. No levels above 0.5 kV were used for I/O testing.




Figure 3.3-1 Conducted Susceptibility Test Configuration





Figure 3.3-2 Burst Transient Waveform

## 4.0 Conclusions

### 4.1 IEC 801-2, ESD Susceptibility

No errors on the port of the EUT were detected for nearfield discharges up through 15 kV. Direct discharges of 2, 4, 6, and 8 kV also did not cause a malfunction. at the 10 kV level, one out of ten discharges caused a loss of communication with the support computer. Since the EN50082-1 requirement ends at 8 kV, the EUT complies with that requirement.

### 4.2 IEC 801-3, Radiated Susceptibility - Electric Field

The test sample was found to be immune to RFI at 10/m from 27 to 500 MHz, in both antenna polarizations, with no modifications.

### 4.3 IEC 801-4, Conducted Susceptibility - Burst Interference Transients


The EUT did not exhibit errors when testing AC ports up through the  $\pm 1$  kV level. At the next level, 2 kV, UPS reboots occurred. I/O cable testing at  $\pm 0.5$  kV also did not cause errors. No levels above 0.5 kV were used for I/O testing.

### 4.4 EN50082-1 Generic Immunity - European Requirements



The SmartShot Call-UPS II Remote Management Device, manufactured by American Power Conversion, is verified as meeting the requirements of EN50082-1:1992.



## Configuration Photographs



## Configuration Photographs



## Article 1 - Services, LABORATORY will:

- 1.1 Act for CLIENT in a professional manner, using the degree of care and skill ordinarily exercised by and consistent with the standards of the profession.
- 1.2 Provide only those services that lie within the technical and professional areas of expertise of LABORATORY and which LABORATORY is adequately staffed and equipped to perform.
- 1.3 Perform all technical services in substantial accordance with the generally accepted laboratory testing principles and practices.
- 1.4 Promptly submit formal reports of technical services performed indicating, where applicable, compliance with specification or other contract documents. Such reports shall be complete and factual, citing where appropriate the technical services performed, methods employed, and values obtained.
- 1.5 Employ instrumentation which has been calibrated within a period not exceeding twelve (12) months from the time of use by devices of accuracy traceable to the National Institute of Standards and Technology of the United States Department of Commerce.
- 1.6 Consider all reports to be the confidential property of client, and distribute reports only to those persons, organizations or agencies designated by CLIENT or his authorized representative.
- 1.7 Retain all pertinent records relating to the services performed for a period of three (3) years following submission of the report or the suspension of manufacturing of product subject to follow-up services, whichever is later, during which period the records will be made available to CLIENT upon reasonable request.

## Article 2 - Client's Responsibilities, CLIENT or his authorized representative will:

- 2.1 Provide LABORATORY with all plans, schematics, specifications, addenda, change orders, drawings and other information for the proper performance of technical services.
- 2.2 Designate a person to act as CLIENT's representative with respect to LABORATORY's services to be performed under this Agreement; such person or firm to have complete authority to transmit instructions, receive information and data, interpret and define CLIENT's policies and decisions with respect to the project and to order, at CLIENT's expense, such technical services as may be required.
- 2.3 Designate a person who is authorized to receive copies of LABORATORY's test reports.
- 2.4 To undertake the following:
  - (a) Secure and deliver to LABORATORY, without cost to LABORATORY, preliminary representative samples of that equipment proposed to require technical analysis, together with any relevant data.
  - (b) Furnish such labor and equipment needed by LABORATORY to handle samples at the LABORATORY and to facilitate the specified technical analysis.

## Article 3 - General Conditions

- 3.1 LABORATORY, by the performance of services covered hereunder, does not in any way assume any of those duties or responsibilities customarily vested in the CLIENT's employees, or any other party, agency or authority.
- 3.2 LABORATORY shall not be responsible for acts or omissions of any other party or parties involved in the design, manufacture or maintenance of the equipment or the failure of any employee, contractor or subcontractor to undertake any aspect of equipment's design, manufacture or maintenance.
- 3.3 LABORATORY is not authorized to revoke, alter, relax, enlarge or release any requirement of the equipment's design, manufacture or maintenance unless specifically authorized by CLIENT or his authorized representative.
- 3.4 This Agreement may be terminated by either party on ten (10) days written notice or by mutual agreement. If this Agreement is terminated by either party, LABORATORY shall be paid in full for all services performed through the termination date, and the CLIENT shall be provided with a complete report of the results of technical analysis conducted prior to termination.
- 3.5 Neither CLIENT nor LABORATORY may delegate, assign, sublet or transfer his duties or interest in this Agreement without the written consent of the other party.
- 3.6 *The only warranty made by LABORATORY in connection with its service performed hereunder is that it will use that degree of care and skill as set forth in Article 1.1 and 1.3 above. No other warranty, expressed or implied, is made or intended for services provided hereunder.*
- 3.7 Where the LABORATORY indicates that additional testing is advisable to obtain more valid or useful data, and where such testing has not been authorized in writing, CLIENT agrees to view such test reports as inconclusive and preliminary.
- 3.8 The LABORATORY shall supply technical service and prepare a report based solely on the sample submitted to the LABORATORY by the CLIENT. The CLIENT understands that application of the data to other devices is highly speculative and should be applied with extreme caution.

- 3.9 The LABORATORY agrees to exercise ordinary care in receiving, preserving and shipping (F.O.B. Boxborough, Mass.) any sample to be tested, but assumes no responsibility for damages, either direct or consequential, which arise or are alleged to arise from loss, damage or destruction of the samples due to the act of examination, modification or testing, or technical analysis, or circumstances beyond LABORATORY's control.
- 3.10 The LABORATORY will hold samples for thirty (30) days after tests are completed, or until the CLIENT's outstanding debts to the LABORATORY are satisfied, whichever is later.
- 3.11 The client recognizes that samples of products subject to LABORATORY's review and test procedures may be damaged or destroyed.
- 3.12 The CLIENT recognizes that generally accepted error variances apply and agrees to consider such error variances in its use of test data.
- 3.13 It is agreed between LABORATORY and CLIENT that no distribution of any test, reports or analysis shall be made to any third party without the prior written consent of both parties. The content of all reports, analysis and tests is strictly confidential and shall not be released to any third party without the written consent of the other party.
- 3.14 The CLIENT acknowledges that all employees of LABORATORY operate under employment contracts with the LABORATORY, and CLIENT agrees not to solicit employment of such employees, or solicit information related to other clients from said employees.

## Article 4 - Follow-Up Services (for listed products only)

- 4.1 If the product is found to be in compliance with the review and test requirements, it is agreed that CLIENT will abide by the Follow-Up Service Procedure.
- 4.2 It is understood and agreed by the CLIENT that the LABORATORY name or listing mark will not be applied or utilized until authorized representatives of LABORATORY have concluded the procedure set forth in Article 4.1.
- 4.3 All costs associated with the Follow-Up Service Procedure will be the responsibility of CLIENT. CLIENT's failure to pay these charges will result in the revocation of authorization to use the LABORATORY listing mark.

## Article 5 - Insurance

- 5.1 LABORATORY shall secure and maintain throughout the full period of this Agreement sufficient insurance to protect it adequately from claims under applicable Workmen's Compensation Acts and from claims for bodily injury, death or property damage as may arise from the performance of services under this Agreement.
- 5.2 The CLIENT hereby warrants that it has sufficient insurance to protect its employees adequately under applicable Workmen's Compensation Acts and for bodily injury, death or property damage as may arise from the acts of its employees pursuant to the Agreement.
- 5.3 No insurance, of whatever kind or type, which may be carried by LABORATORY is to be considered as in any way limiting any other party's responsibility for damages resulting from their operations or for furnishing work and materials related to the project.

## Article 6 - Payment

- 6.1 CLIENT will pay LABORATORY for services and expenses. LABORATORY's invoices will be presented at the completion of its work or monthly and will be paid within thirty (30) days of receipt by CLIENT or his authorized representative.
- 6.2 LABORATORY shall be paid in full as described in Article 6.1 and, in addition, shall be paid in full for any services authorized orally or in writing by an employee or agent of the CLIENT pursuant to Article 2.2.

## Article 7 - Extent of Agreement

The Agreement, including these Terms and Conditions and the Schedules attached hereto, represent the entire agreement between CLIENT and LABORATORY and supersedes all prior negotiations, representations or agreements, written or oral. The Agreement may be amended only in accordance with this Agreement or by written instrument signed by CLIENT and LABORATORY.

## Article 8 - Collection

- 8.1 CLIENT shall pay LABORATORY interest in the amount of one and one half percent (1.5%) per month on amounts invoiced which are overdue. Invoices which are overdue are defined as those which remain unpaid more than thirty (30) days after presentation.
- 8.2 CLIENT agrees to pay LABORATORY all amounts incurred by LABORATORY in collecting on invoices which are overdue. Such amounts shall include, but shall not be limited to, reasonable attorneys' fees and court costs.