



DE 1 - 31415

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product  
Produit

Uninterruptible Power Supply (UPS)

Name and address of the applicant  
Nom et adresse du demandeur

American Power Conversion Corp.  
85 Rangeway Road Building 2,  
NORTH BILLERICA MA 01862, USA

Name and address of the manufacturer  
Nom et adresse du fabricant

American Power Conversion Corp.  
85 Rangeway Road Building 2,  
NORTH BILLERICA MA 01862, USA

Name and address of the factory  
Nome et adresse de l'usine

see attached page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Input: AC 220-240 V, 6 A, 50/60 Hz or  
AC 220-240 V, 12 A, 50/60 Hz  
Output: AC 220-240 V, 4.6 A, 50/60 Hz, 700W, 1000 VA or  
AC 220-240 V, 9.16 A, 50/60 Hz, 1400W, 2000 VA

Trademark (if any)  
Marque de fabrique (si elle existe)

APC

Model / Type Ref.  
Ref. De type

SURT1000XLICH, SURT1000UXICH, SURT2000XLICH,  
SURT2000UXICH, SUOL1000XLI, SUOL2000XLI,  
SUOL1000UXI, SUOL2000UXI, SURT1000XLI,  
SURT2000XLI, SURT1000UXI, SURT2000UXI

Additional information (if necessary)  
Information complémentaire (si nécessaire)

Class I,

WMT

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 62040-1-1(ed.1);corrigendum

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

1924400-3335-0020

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

**VDE** VERBAND DER ELEKTROTECHNIK  
ELEKTRONIK INFORMATIONSTECHNIK e.V.  
**VDE** Prüf- und Zertifizierungsinstitut  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle / Certification  
Date: 2004-11-30

  
Signature:

**CB certificate DE 1 – 31415**  
**File ref. 1924400-3335-0020**

**Place(s) of manufacture**

**APC India Pvt. Ltd.**  
187/3 & 188/3 Jigani Village  
Jigani Hobli  
562106 BANGALORE  
INDIEN

**APC (Suzhou) UPS Co., Ltd.**  
No. 339 Suhong Road  
Suzhou Industry Park  
215021 SUZHOU JIANGSU  
CHINA

**American Power Conversion  
Plant 2**  
Lot 32, Phase I, Carmelray Ind. Park,  
PEZA, Canlubang,  
CALAMBA, LAGUNA,  
PHILIPPINEN

**American Power Conversion  
CAV 1**  
2nd Street, PEZA,  
Cavite Economic Zone  
ROSARIO, CAVITE  
PHILIPPINEN