CERTIFICATION

1163

Applicant	: American Power Conversion Holding Inc. Taiwan Branch		
Address	: 4F, No. 205, Sec. 3, Beishin Rd., Shindian City, Taipei, Taiwan, 231, R.O.C.		
Manufacturer	: American Power Conversion Holding Inc. Taiwan Branch		
Address	: 4F, No. 205, Sec. 3, Beishin Rd., Shindian City, Taipei, Taiwan, 231, R.O.C.		
Description of EUT	: Uninterruptible Power System		
Trade Name	: APC		
Model Number	: BE400-FR, BE400-GR, BE400-IT, BE400-RS, BE400-SP, BE400-UK		
Serial Number	: N/A		
Type of Test	: EMC Directive 89/336/EEC for CE Marking		
Technical Standard	**EN 50091-2**	**: 1995**	**Emission**
	EN 55022	: 1998	Class B / CISPR-22: 1997 Class B
	IEC 61000-3-2	: 2000	Power Harmonics
	IEC 61000-3-3	: 1995	Voltage Fluctuation / Flicker
	EN 50091-2	**: 1995**	**Immunity**
	IEC 1000-2-2	: 1990	Low Frequency Signal
	IEC 801-2	: 1991	Electrostatic discharge
	IEC 801-3	: 1984	Radiated radio-frequency, electromagnetic field
	IEC 801-4	: 1988	Electrical fast transient / burst
Report Number	**: HA050027-CE**		
Issued Date	**: 24-AUG-2005**		
Test Result	**: Compliance**		

The above equipment was tested by *HongAn* TECHNOLOGY CO., LTD. , for compliance with the requirement set forth in EMC Directive 89/336/EEC (Amened by 92/31/EEC & 93/68/EEC) and the technical standards mentioned above.

Note :

1. The results of the testing report relate only to the items tested.

2. The testing report shall not be reproduced except in full, without the written approval of *HongAn* TECHNOLOGY CO., LTD.

Test by : L.H.HUNG K.C.LEE

Approve & Authorized : L. A. HSU EMC Lab. Manager

***HongAn* TECHNOLOGY CO., LTD.**
NO.15-1,CWESISHUH KENG,CWEIPIN VILLAGE,
LINKOU,TAIPEN COUNTY, TAIWAN, R.O.C.

TEL : 886-2-26030362
FAX : 886-2-26019259
E-mail : hatlab@ms19.hinet.net

BSMI Registration No.: SL2-IN-E-0023,SL2-IS-E-0023, SL2-A1-E-0023,SL2-R1-E-0023, SL2-R2-E-0023
FCC Designation Numer: TW1001

Nemko authorization No.:ELA184
CNLA Registration No . :1163
VCCI Registration No . :R-2156, C-2329, T-219