



NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES.
2. SEE PRODUCT DOCUMENTATION FOR FURTHER INFORMATION PRIOR TO INSTALLATION.
- △ 3. UTILITY SOURCE MUST BE 2WIRE+GROUND, PROVIDED BY OTHERS. RECOMMENDED INPUT BRANCH CIRCUIT BREAKER RATINGS: FOR SINGLE-PHASE INPUT, 60A; FOR TWO-PHASE INPUT, 30A.
- △ 4. DASHED LINES (- - -) REPRESENT CABLING PROVIDED BY OTHERS.
5. RECOMMENDED MAXIMUM OUTPUT BREAKER RATING IS 60A. MAXIMUM VA IS LIMITED TO 10kVA.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:
 STEP-DOWN TRANSFORMER
 INPUT: 208VAC, 1Ø OR 480VAC, 2Ø
 OUTPUT: 10kVA, 120VAC OR 208VAC
 SYSTEM SINGLE-LINE DIAGRAM

DWG NO:	APTF10KT01-SD		REV:	1
DRAWN BY:	BALAMURUGAN/S CUNHA	23-MAY-12	PROJ	ANGLE
ENGINEER:	K WHITE/B BUNGCAYAO	13-SEP-07	APPROVED BY:	M TAVARES
PROJECT:	STD SUBMITTAL DRAWINGS	SHEET 1 OF 1	13-SEP-07	N/A