

## SHORT FRAME, DOUBLE POD, DUCTED CEILING WITH RACKS ONLY



# NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES]
- 4. WEIGHT REFER TO THE RESPECTIVE SUBMITTALS.
- △ 5. THIS DIMENSION MAY VARY AS PER RACK WIDTH AND NUMBER OF RACKS. SHOWN TYPICAL ARRANGEMENT FOR TWELVE 600mm WIDE RACKS. TELESCOPING BEAM CAN ACCOMMODATE ANY COMBINATION OF RACKS FROM 8-12 FEET.
- △ 6. SHORT FRAME CAN ACCOMMODATE UP TO 48U, SHOWN TYPICAL ARRANGEMENT FOR 42U RACKS.

  REFER TO TABLE FOR DETAILS.
  - KEPER TO TABLE FOR DETAILS.
- 7. THIS DRAWING IS FOR TYPICAL CONFIGURATION.




<u>^</u>						
RACK HEIGHT		DUCT RISER HEIGHT				
U	m	ım [inch]				
42U	1991 [78.39]	2757 [108.56]				
45U	2124 [83.64]	2890 [114.90]				
48U	2258 [88.90]	3024 [120.16]				

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric	S
	г

	TITLE:  HYPERPOD SHORT FRAME, DOUBLE POD, DUCT RAISEF	SEDPDRWR			REV.
	WITH RACK AND W/O DISTRIBUTION PANEL		BALA	02-JUN-17	FIRST
FRÖNT VIEW		ENGINEER:	A COTTER	02-JUN-17	angle
	PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3	APPROVED BYE	SYMONS	02-JUN-17	PRA

## SHORT FRAME, DOUBLE POD, DUCTED CEILING WITH RACKS ONLY



# RACK DEPTH mm [inch] 825 [32.480] 1070 [42.125] 1200 [47.244]

### NOTES


- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- A4. OVERALL CONTAINMENT POD WIDTH DIMENSION MAY VARY AS PER THE COMPONENT SELECTED. 1070 [42.13] DEPTH RACK SHOWN FOR TYPICAL ARRANGEMENT. REFER TO TABLE FOR DETAILS.
- $\Delta$ 5. This dimension may vary as per the rack selected. 42U rack shown for typical arrangement.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



l	TITLE: HYPERPOD SHORT FRAME, DOUBLE POD, DUCT RAISER	DWG NO: SFDPDRWR			REV.	
	WITH RACK AND W/O DISTRIBUTION PANEL			BALA	02-JUN-17	FIRS
RIGHT' SIDE VIEW		ENGINEER:	A COTTER	02-JUN-17	ANGL	
Ī	PROJECT: SUBMITTAL DRAWINGS	SHEET 2 OF 3	APPROVED BYR	SYMONS	02-JUN-17	PRO.

## SHORT FRAME, DOUBLE POD, DUCTED CEILING WITH RACKS ONLY



**A** 

AISLE WIDTH				
Feet	mm [inch]			
3	914.4 [36.0]			
4	1219.2 [48.0]			
5	1524.0 [60.0]			
6	1828.8 [72.0]			

TOP VIEW

## NOTES:

- 1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- △4. ACROSS AISLE DIMENSION MAY VARY AS PER THE REQUIREMENT.

  TABLE SHOWS STANDARD CONFIGURATION.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:  HYPERPOD  SHORT FRAME, DOUBLE POD, DUCT RAISER		DWG NO:	FDPD	RWR	REV.	
	WITH RACK AND W/O DISTRIBUTION PANEL		DRAWN BY:	BALA	02-JUN-17	FIRST
			ENGINEER:	A COTTER	02-JUN-17	ANGLE
	PROJECT: SUBMITTAL DRAWINGS	SHEET 3 OF 3	APPROVED BYR	SYMONS	02-JUN-17	PROJ