



Ref. Certif. No.

JPTUV-134760-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Power Systems
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No.189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494, Taiwan
Name and address of the manufacturer	American Power Conversion Holdings Inc., Taiwan Branch 5F., No.189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494, Taiwan
Name and address of the factory	Shenzhen KSTAR Science And Technology Co.,Ltd. Guangming Branch Kstar Industrial Park, 7th Road, Guangming Hi-Tech Industrial Zone, Shenzhen, P.R. China
Ratings and principal characteristics	Input : 220-240Vac, 1Ø+N+PE, 50-60Hz 380-415Vac, 3Ø+N+PE, 50-60Hz Output: 220/230/240Vac, 1Ø+N+PE, 50-60Hz 380/400/415Vac, 3Ø+N+PE, 50-60Hz For more information of ratings, refer to the test report.
Trademark (if any)	APC
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	UPS: SURTaKUXIc-xx, SRTGaKXLlB, (variable a=15 or 20, b= -PM or blank, c=G or blank, x=A to Z for marketing purpose only) External Battery Cabinet: SRTG192XLBP2, SURT192XLBPG2 Parallel Kit: SURTPKG01, SRTGPK01
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report Re-issue of JPTUV-134760 dated 2022-05-10, due to first modification.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017+A1 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	CN21HQSX 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2023-07-10

Signature:

Jason Tang