

IEC**IECEE**

®

TM

Ref. Certif. No.

JPTUV-133659

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Uninterruptible Power Supply
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the manufacturer	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the factory	AblereX Electronics (Suzhou) Co., Ltd. No. 36 WangWu Road Suzhou City, Jiangsu, P.R. China
Ratings and principal characteristics	Input: AC 220-240V; 1) 3.9A, 2) 4.9A; 50/60Hz ; 1Ø; Class I Output: refer to the test report.
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) SMVS750IXXXXXXXX, SMVS750CAIXXXXXXXX 2) SMVS1000IXXXXXXXX, SMVS1000CAIXXXXXXXX (X=A-Z, 0-9, - or nil)
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017 IEC 62040-1:2017+A1 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22W65H 001

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland**®

TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2022-03-28

Signature:


Dipl.-Ing. (FH) A. Klinker