

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Multiple portable socket-outlets with SPD(s)

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City
Taiwan

Name and address of the manufacturer

Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong
China

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong
China

Ratings and principal characteristics

16 A, 250 V~, MAX. 2500 W (Limited to 10 A by means of circuit breaker)

Trademark (if any)

APC or APC by Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PM6-GR, PM6-RS, PM8-GR, PM8-RS, PMF83VT-GR, PMF83VT-RS

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

This CB Test Certificate is an addition to CB NL-34899 with Test Report Number 4318493.50/51 dated 2015-02-28 due to deleted models, updated standard, added Trade Mark, updated enclosure and shutter box and changed applicant.

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013, IEC 60884-2-7:2011, IEC 60884-2-7:2011/AMD1:2013, IEC 61643-11:2011, IEC 61643-21:2000, IEC 61643-21:2000/AMD1:2008, IEC 61643-21:2000/AMD2:2012

National differences:

DE, NL

As shown in the Test Report Ref. No. which forms part of this Certificate

4377516.50/51+6109441.50+6110764.51/52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands