

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Multiple portable socket-outlets with SPD(s)
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City Taiwan
Name and address of the manufacturer	Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	16 A, 250 V~ (MAX. 2300 W, 230 V~, 10 A, limited by means of circuit breaker)
Trademark (if any)	APC or APC by Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	PM5-FR, PM5V-FR, PM5T-FR
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This CB Test Certificate is an addition to CB NL-34900 with Test Report Number 4318925.50.51 dated 2015-02-28 due to updated standard, updated enclosure and shutter box and changed applicant.
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013, IEC 60884-2-7:2011, IEC 60884-2-7:2011/AMD1:2013, IEC 61643-11:2011, IEC 61643-21:2000, IEC 61643-21:2000/AMD1:2008, IEC 61643-21:2000/AMD2:2012  National differences: FR 4377291.50/51+6110764.50/51/52
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands