

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device, incorporated in plug-in adaptors

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City,
Taiwan

Name and address of the manufacturer

Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong,
China

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong,
China

Ratings and principal characteristics

Test class III / Type 3, Uc: 250 V~, Uoc: 6 kV(L-N, L/N-PE),
Up: 2,3 kV(L-N, L/N-PE), Isccr: 1,5 kA, IP20

Trademark (if any)

APC or APC by Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SBA108 REV:A0 incorporated in adaptor models PM1W-GR,
PM1WB-GR, PM1WU2-GR, PM1W-RS, PM1WB-RS, PM1WU2-
RS, PM1WB-TR, PMA1WG-TR, PM1W-FR, PM1WU2-FR, PM1W-
IT and PM1WU2-IT (Total 12 models)Additional information (if necessary may also be
reported on page 2)☐ Additional information on page 2A sample of the product was tested and found
to be in conformity with

IEC 61643-11:2011

National differences:
EU Group Differences
6106895.50As shown in the Test Report Ref. No. which
forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands