

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device, incorporated in multiple portable socket- outlets
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City, Taiwan
Name and address of the manufacturer	Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Dongguan Quan Sheng Electric Co., Ltd. 2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan, Guangdong, China
Ratings and principal characteristics	Test class III / Type 3, Uc: 250 V~, Uoc: 6 kV(L-N, L/N-PE), Up: 2,3 kV(L-N, L/N-PE), Iscrr: 1,5 kA, IL:10 A, IP20
Trademark (if any)	APC or APC by Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	SBA5_REV:A.1 incorporated in socket-outlets models PM5-GR, PM5-RS, PM5B-RS, PM5T-GR, PM5V-GR, PM5V-RS, PM5U-GR, PM5U-RS, PM5-FR, PM5V-FR, PM5T-FR, PM5U-FR, PM5-IT (Total 13 models)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6110764.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

