

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Powersupplies (UPS) (Uninterruptible Power Supply)
Name and address of the applicant	AMERICAN POWER CONVERSION HOLDINGS INC., TAIWAN BRANCH 5F., NO.189, SEC. 2, JIUZONG RD., NEIHU DIST. 11494 TAIPEI CITY TAIWAN
Name and address of the manufacturer	AMERICAN POWER CONVERSION HOLDINGS INC., TAIWAN BRANCH 5F., NO.189, SEC. 2, JIUZONG RD., NEIHU DIST., 11494 TAIPEI CITY, TAIWAN
Name and address of the factory	Zhongshan Voltronic Power Electronics Limited No.8 Shichong Road, Zhongshan Torch Hi-Tech Industrial Development Zone, 528437 Zhongshan, Guangdong, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	Ratings: For main unit: AC input: 220-240VAC, 50-60Hz, 34.5A Max., 1 Phase+N+PE; AC output: 220/230/240VAC, 50/60Hz, 27.3A Max., 6kVA / 6kW, 1 Phase+N+PE; Icc≤6kA For external battery module: Nominal Voltage: 48VDC Nominal Capacity: 100Ah Protection Class: I
Trademark / Brand (if any)	APC, Schneider Electric
Model/type Ref.	For main unit: SRVLP6KRIL, SRVL6KRIL, SRVL6KRILRK; For external battery module: SRVL48RMBP3U
Additional information (if necessary)	See Test Report for National Differences and Group Differences.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017 IEC 62040-1:2017/AMD1:2021 IEC 62040-1:2017/AMD2:2022
as shown in the Test Report Ref. No. which forms part of this certificate	211-902628-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 060807 0079 Rev. 00

Date, 2026-05-21



(Terry Wei)



Ref. Certif. No.

SG PSB-OF-07492

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 060807 0079 Rev. 00

Date, 2026-05-21

(Terry Wei)

TÜV SÜD PSB Pte Ltd

15 International Business Park TÜV SÜD @ IBP

Singapore 609937

