

Certificate of Conformity

issued by Curtis-Straus

Company: APC Corporation
Product Tested: SUA750RMI1U
Also Compliant: EMC750RMI1U
Testing Date: June 26, 29-30 and July 2 - 3, 2007
Report No.: EH0753-1

A sample of the product as configured in the accompanying test report has been found to comply with the following standards:

EMC Emissions:

- EN 55022:1998/A1:2000/A2:2003 Class A ITE emissions requirements (EU)
- ICES-003 Issue 4 Class A Digital Apparatus emissions requirements (Canada)
- FCC 47 CFR Part 15 Class A emissions requirements (USA)
- VCCI Class A ITE emissions requirements (Japan)
- AS/NZS CISPR 22:2002 Class A ITE emissions requirements (Australia)
- EN 61000-3-2:2006 Limits for harmonic current emissions (equipment input current up to and including 16A per phase)
- EN 61000-3-3:2005 Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current up to and including 16 A

Registration numbers for all open area test sites can be found in the *Test Equipment Used* Section starting on page 44 of the attached report.

EMC Immunity:

- EN 55024:1998/A1:2001/A2:2003 ITE - immunity characteristics

Attested to by the hands and seals:

For Curtis-Straus

For the Manufacturer or Importer


Test Engineer Date

Date


EMC Manager Date