



Ref. Certif. No.

JPTUV-163261

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|--|
| Product | Uninterruptible Power Supply |
| Name and address of the applicant | American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan |
| Name and address of the manufacturer | American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan |
| Name and address of the factory | See additional page(s) for the listing of 3 factories |
| Ratings and principal characteristics | i/p: AC 220-240V or AC 230V; 10A; 50/60Hz ; 1Ø; Class I o/p: Surge Only Outlets: AC 220-240V; 50/60Hz or AC 230V; 50/60Hz 1) Battery Backup Outlets: AC 230V; 50/60Hz; 1500VA; 865W 2) Battery Backup Outlets: AC 230V; 50/60Hz; 1200VA; 720W Total Outlet Current: 10A MAX |
| Trademark / Brand (if any) | APC |
| Customer's Testing Facility (CTF) Stage used | N/A |
| Model / Type Ref. | 1) BR1500GXYYYYYY 2) BR1200GXYYYYYY (X=I, -FR or -GR; Y= any alphanumeric, +, *, #, _, - or blank) |
| Additional information (if necessary may also be reported on page 2) | For model differences, refer to the test report. |
| A sample of the product was tested and found to be in conformity with | IEC 62040-1:2017+A1+A2 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | CN24BFJV 001 |

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Mail: info@jpn.tuv.com

Date: 2024-07-29

Signature: Dipl.-Ing. Th. Illing

10/0615MD 2022-07 rke-fix