



Ref. Certif. No.

JPTUV-101086

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Power Supply
Name and address of the applicant	American Power Conversion Holding Inc., Taiwan Branch 3F., No. 205, Sec. 3, Beixin Rd., Xindian Dist. New Taipei City 231 Taiwan
Name and address of the manufacturer	American Power Conversion Holding Inc., Taiwan Branch 3F., No. 205, Sec. 3, Beixin Rd., Xindian Dist. New Taipei City 231 Taiwan
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	Input: AC 220-240V; 50/60Hz; 10A; 1Ø; Class I Output: refer to the test report.
Trademark (if any)	APC
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	BR1500GXXXXXX BR1200GXXXXXX (X = I, -FR or -GR; Y = any alphanumeric, +, *, #, _, hyphen or blank)
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2008+A1 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	50267203 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021 Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web: www.tuv.com

Dipl.-Ing F. Stoelzel

Date: 08.10.2019

Signature:


1. International Precision Assemblies,  
Inc.  
Lot 6, Blk 8, Phase II Peza  
Rosario Cavite 4106  
Philippines
2. International Precision Assemblies,  
Inc. Plant 2  
Lot 2, Blk 17, Phase IV Peza  
Rosario Cavite 4106  
Philippines

**Additional information (if necessary)**  
**Information complémentaire (si nécessaire)**

Report Ref. No.: 50267203 001

Date: 08.10.2019

Signature:

  
Dipl.-Ing. F. Stoelzel