

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Power Supply
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the manufacturer	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	i/p: AC 220-240V or AC 230V; 10A; 50/60Hz ; 1Ø; Class I o/p: Surge Only Outlets: AC 220-240V; 50/60Hz or AC 230V; 50/60Hz 1) Battery Backup Outlets: AC 230V; 50/60Hz; 1500VA; 865W 2) Battery Backup Outlets: AC 230V; 50/60Hz; 1200VA; 720W Total Outlet Current: 10A MAX APC
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) BR1500GXXXXXX 2) BR1200GXXXXXX (X = I, -FR or -GR; Y= any alphanumeric, +, *, #, _, - or blank)
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report. Re-issue of JPTUV-131034 dated 2021-12-27, due to first modification.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN21I992 002

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2024-01-19

Signature:

Dipl.-Ing. Th. Illing