

Verification of Compliance

Product Name : Uninterruptible power supply

Model Number : SMVS750IXXXXXXXX, SMVS1000IXXXXXXXX,
SMVS1500AIXXXXXXXX, SMVS750CAIXXXXXXXX,
SMVS1000CAIXXXXXXXX, SMVS1500CAIXXXXXXXX
SMVS2000AIXXXXXXXX, SMVS3000AIXXXXXXXX,
SMVS2000CAIXXXXXXXX, SMVS3000CAIXXXXXXXX
(X= 0-9, A-Z, nil or -)

Applicant : American Power Conversion Holdings Inc., Taiwan Branch

Address : 3F, No. 205, Sec. 3, Beixin Rd. Xindian Dist. New Taipei City 231
Taiwan

Report Number : S1C-A560-1808-125

Issue Date : January 16, 2019

Applicable Standards : EN 62040-2:2006+AC2006 (Category C2)
IEC 62040-2:2005
EN 61000-3-2:2014
EN 61000-3-3:2013
EN 61000-4-2:2009
EN 61000-4-3:2006+A1:2008+A2:2010
EN 61000-4-4:2012
EN 61000-4-5:2014
EN 61000-4-6:2014
EN 61000-4-8:2010
EN 61000-2-2:2002

Based on the specifications of the customer, one sample of the designated product has been tested in our laboratory and found to be in compliance with the EMC standards cited above.



TAF 0905

FCC CAB Code TW1104, TW0019

NVLAP Lab Code 200575-0

IC Code 4699A

VCCI Accep. No. R-11527, C-11609, T-11441, G-10010

C-20010, T-20009, G-10614



Central Research Technology Co.

EMC Test Laboratory

11, Lane41, Fushuen St., Jungshan Chiu,

Taipei, Taiwan, 104, R.O.C.

Tel : 886-2-25984568

Fax: 886-2-25984546

(Tsun-Yu Shih/ General Manager)

Date: January 16, 2019