



# Certificate

Certificate no.

CU 72100792 01

**License Holder:**  
American Power Conversion Corp.  
85 Rangeway Road  
North Billerica MA 01862  
USA

**Manufacturing Plant:**  
APC Philippines  
Lot 10, Block 16, Phase IV  
PEZA, Rosario, Cavite  
Philippines

**Test report no.:** USA-KE 30981121 001

**Client Reference:** M. Landsman

**Tested to:** UL 60950-1:2007  
CAN/CSA-C22.2 No.60950-1-07

**Certified Product:** Bypass Switch

**License Fee - Units**

**Model Designation:** 1) SBP20KP, 2) SBP20KRMT4U,  
3) SBP20KRMI4U

7

**Rated Voltage:** 1a) 2/PE AC 200V, 208/240V, 50/60Hz  
1b) 1/N/PE AC 220/230/240V, 50/60Hz;  
3/N/PE AC 380/400/415V, 50/60Hz  
2) 2/PE AC 200V, 208/240V, 50/60Hz  
3) 1/N/PE AC 220/230/240V, 50/60Hz;  
3/N/PE AC 380/400/415V, 50/60Hz

**Rated Current:** 125A  
**Protection Class:** I

contd.

7

**Appendix:** 1, 1-2  
Inh. = 710370 / Deb. = 710370 / Fert. = 751015

**Licensed Test mark:**



**Signature**

**Dipl.-Ing. M. Glagla**  
**QA Certification Officer**

**Date of Issue**  
**(day/mo/yr)**

09/06/2010



# Certificate

Certificate no.

CU 72100792 02

**License Holder:**

American Power Conversion Corp.  
85 Rangeway Road  
North Billerica MA 01862  
USA

**Manufacturing Plant:**

APC Philippines  
Lot 10, Block 16, Phase IV  
PEZA, Rosario, Cavite  
Philippines

**Test report no.:** USA-KE 30981121 001

**Client Reference:** M. Landsman

**Tested to:** UL 60950-1:2007  
CAN/CSA-C22.2 No.60950-1-07

**Certified Product:** Bypass Switch

**License Fee - Units**

contd.

Output Ratings: 1a) 2/PE AC 200, 208/240V, 50/60Hz, 125A  
1b) 1/N/PE AC 220/230/240V, 50/60Hz, 125A  
2) 2/PE AC 200, 208/240V, 50/60Hz, 125A  
3) 1/N/PE AC 220/230/240V, 50/60Hz, 125A

Inh. = 710370 / Deb. = 710370 / Fert. = 751015

Licensed Test mark:



Signature

A handwritten signature in blue ink, appearing to read "Martin Glagla".

Dipl.-Ing. M. Glagla  
QA Certification Officer

Date of Issue

(day/mo/yr)

09/06/2010