


CERTIFICATE OF CONFORMITY



Equipment : UPS
Brand Name : APC
Test Model No. : SRC3000XLI, SRC3000UXI
Multiple Listing : SRC3000XLIXXX, SRC2000XLIXXX, SRC1000XLIXXX,
SRC3000UXIXXX, SRC2000UXIXXX, SRC1000UXIXXX
("XXX" could be -CH or -CC or blank for different plug)
Applicant : American Power Conversion Holding Inc, Taiwan Branch
Test Report No. : CE971007A08

We, **Advance Data Technology Corp.**, declare that the equipment above has been tested in our facility and found compliance with the requirement limits of applicable standards. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.

EN 62040-2: 2006, Category C2

IEC 61000-3-2: 2005 ED.3.0

IEC 61000-4-2 : 2001 ED.1.2

IEC 61000-4-3: 2006 ED.3.0

IEC 61000-4-4: 2004 ED.2.0

IEC 61000-4-5: 2005 ED.2.0

IEC 61000-4-6: 2006 ED.2.2

IEC 61000-4-8: 2001 ED. 1.1

IEC 61000-2-2: 2002 ED.2.0



Kenny Meng

Kenny Meng / Deputy Manager Linkou EMC / RF Lab. ADT CORP.



No. 47, 14th Ling, Chia Pau Tsuen, Lin Kou Hsiang, Taipei Hsien, 244

Taiwan, R.O.C. Tel: 886-2-26052180 Fax: 886-2-26051924

<http://www.adt.com.tw> E-Mail: service@adt.com.tw