

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Uninterruptible power supply (UPS)

Name and address of the applicant
Nom et adresse du demandeur

American Power Conversion Corp.
85 Rangeway Road Building #2, NORTH BILLERICA MA 01862
UNITED STATES OF AMERICA

Name and address of the manufacturer
Nom et adresse du fabricant

American Power Conversion Corp.
85 Rangeway Road Building #2, NORTH BILLERICA MA 01862
UNITED STATES OF AMERICA

Name and address of the factory
Nom et adresse de l'usine

AMERICAN POWER CONVERSION CORPORATION (A.P.C.)
B.V.
2nd Street, PEZA, Cavite Economic Zone, 4106 ROSARIO,
CAVITE
PHILIPPINES

Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2^{ème} page

☒ Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input: AC 220 - 240 V, max. 16 A, 50/60 Hz
Output: AC 220 - 240 V, 560/60 Hz

Trademark (if any)
Marque de fabrique (si elle existe)

APC

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

TMP

Model / Type Ref.
Ref. De type

Smart - UPS, SMC3000I, SMC3000RM12U
See model matrix for details

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,
peuvent être indiqués sur la 2^{ème} page)

Class I
IEC 62040-1(ed.1);corrigendum1

☐ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 62040-1(ed.1)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

1924400-3335-0041/192122

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification



Date: 2014-02-05

Signature:



Ref. Certif. No.

DE1-49406/M1

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV., 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Additional information (if necessary)
Information complémentaire (si nécessaire)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

Date: 2014-02-05

Signature:

E. Biehl



Ref. Certif. No.

DE1-49406/M1

VDE-File-Ref. 1924400-3335-0041/192122

MODEL MATRIX

W W W W X X X X X Y Y Y Y Y Y Y Z Z Z Z Z

W W W W = MANUFACTURERS PREFIX A TO Z (may take up to 5 characters)

Low Voltage Isolated Secondary Differences Only (Non-Safety Critical)

X X X X X = VA OUTPUT 0 TO 9 (may take up to 5 characters)

See Current VA Levels below:

2200, 3000

Y Y Y Y Y Y Y = UNIT CONFIGURATION A TO Z and/or 0 to 9 (may take up to 10 alphanumeric characters)

Current UPS Configurations : I = International, R or RM = Rack Mount, XL = Extended Run, U = Unit Height,

NET = Software in shipping box, PS = Power Switch, B = Black Bezel, BP = Battery Pack, DR = Din Rail Mount

Z Z Z Z Z = X followed by up to a three digit number 0 to 9 (may take up to 6 characters) [Non safety critical difference only]

Example of how to use Matrix: SUA 2200 I BX122

WWWW XXXXX YYYYYYYY ZZZZZZ

Product Voltages (all units): 220VAC-240VAC

Product Frequency (all units): 50/60Hz

Maximum Input Current: 16 A

Present Model Prefixes Example: APC, Bay, BP, CH, DL, DLA, DLT, DIG, IBM, NS, PR, PS, SAM, SU, UNS, Suvs, SUA, **SMC**, SMT

Example of Models Covered by Matrix:

SUA2200I, SUA2200XLI, SUA2200RMI2U, DLT2200I, SUA3000I,

SUA3000XLI, SUA3000RMI2U, SUA3000RMXLI3U, SMT2200I, SMT2200RMI2U, SMT3000I, SMT3000RMI2U, DLT3000RMI2U, **SMC3000I, SMC3000RMI2U**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification