



Ref. Certif. No.

JPTUV-137291

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible Power Supply

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the manufacturer

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

Input: AC 220-240V; 5A; 50-60Hz; 1Ø; Class I  
Output(UPS Outlet / Surge Outlet): refer to the test report.

Trademark (if any)

APC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) BK500EIyyyyyy  
2) BK350EIyyyyyy  
3) BK325I  
(yyyyyy = 0 to 9, A to Z, "-" or blank, for marketing use only)

Additional information (if necessary may also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN227501 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021, Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web : www.tuv.com

Date: 2022-07-15

Signature:

Dennis Chiu

10081 CB 06/2019 HK