

Date : 31.10.2022

American Power Conversion Holdings
Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 11494
Taiwan, R.O.C.
Attn: Ken Hsieh

Re. : CU US + Canada Certificate

Type of Equipment : Uninterruptible Power Supply
Model Designation : See Certificate
Certificate No. : CU 72213596 0004
File No. : 30883419 020
Engineer/Contact : Andreas Klinker
Standard(s) : UL 1778:2014
CSA C22.2 NO. 107.3-14

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72213596 0004.
It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document.
For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body

H. Lin 
QA Certification Officer

Enclosure

Certificate



Certificate no.

CU 72213596 04

License Holder:

American Power Conversion Holdings
Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 11494
Taiwan

Manufacturing Plant:

Fuhong Precision Component
(Bac Giang) Company Limited
Lot P (P1) and P (P2), Quang Chau
Industrial Park, Viet Yen District,
220000 Bac Giang Province,
Vietnam

Test report no.: USA-AK 30883419 020

Client Reference: 238061165/JL17082022

Tested to:

UL 1778:2014
CSA C22.2 NO. 107.3-14

Certified Product: Uninterruptible Power Supply

License Fee - Units

Addition:

Model Designation: BN1050MXXXXXXXX

(X = 0-9, a-z, A-Z, +, *, #, -, or blank)

Rated Voltage : AC 120V, 60Hz, 1Ø

Rated Current : 12A

Battery Backup Outlets: AC 120V, 60Hz, 8.75A, 600W, 1050VA

Surge Only Outlets : AC 120V, 60Hz

Total Output Current : 12A

Protection Class : I

Addition:

Manufacturing Plant: see above

(K2264212)

Appendix: 1, 1-25

Licensed Test mark:



Date of Issue

(day/mo/yr)

31/10/2022